


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

X Location of well:		County <b>Gray County</b>	Section <b>NE 1/4 SW 1/4 SE 1/4</b>	Section number <b>30</b>	Township number <b>T 26 S</b>	Range number <b>R 29 E/W</b>
2. Distance and direction from nearest town or city: <b>1 East of Charleston on Hiway 50, 2 1/2 South, 3/4 East, 5 South, 1/2 East</b>			Owner of well: <b>J. E. Jury</b> R.R. or street: <b>R. R. #1</b> City, state, zip code: <b>Farmington, Iowa 52626</b>			
4. Locate with "X" in section below: 			6. Bore hole dia. <b>26</b> in. Completion date <b>10-31-78</b> Well depth <b>220</b> ft.			
5. Type and color of material			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary			
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
			9. Casing: Material <b>Steel</b> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>1 ft.</b> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <b>36.87</b> lbs./ft. Dia. <b>16</b> in. to <b>220</b> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <b>219</b>			
			10. Screen: Manufacturer's name <b>Johnson</b> Type <b>Johnson Galv. D 100-16"</b> Slot/gauze <b>0-110 Plain 110-145 Perf.</b> Set between <b>145-155 Screen 155-185 Perf.</b> <b>185-215 Screen 215-220 Perf.</b> Gravel pack <b>yes</b> Size range of material <b>1/4 to 5/8</b>			
			11. Static water level: <b>79</b> ft. below land surface Date <b>9-29-78</b>			
(Use a second sheet if needed)			12. Pumping level below land surfaces: <b>150</b> ft. after <b>2</b> hrs. pumping <b>800</b> g.p.m. <b>178</b> ft. after <b>4</b> hrs. pumping <b>1050</b> g.p.m. Estimated maximum yield <b>1050</b> g.p.m.			
			13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date			
			14. Well head completion: <input type="checkbox"/> Pitless adapter <b>1 ft.</b> inches above grade			
			15. Well grouted? <b>yes</b> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <b>0</b> ft. to <b>10</b> ft.			
			16. Nearest source of possible contamination: ft. <input type="checkbox"/> Direction <b>N/A</b> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
18. Elevation:  Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley			17. Pump: Manufacturer's name <b>Could 5 stg. 12" Bowl</b> Not installed Model number <input type="checkbox"/> HP <b>100</b> Volts <input type="checkbox"/> Length of drop pipe <b>200</b> ft. capacity <b>1000</b> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Minter-Wilson Drilling Co. 208</b> Business name <b>Box A, Garden City, KS</b> License No. <b>67846</b> Address <b>Box A, Garden City, KS</b> Date <b>10-29-78</b> Authorized representative			
19. Remarks:						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

# MINTER-WILSON DRILLING CO.

INCORPORATED

Commercial  
and Domestic  
Water Systems  
Complete Installation  
and Repairing

Phone 336-8700

P.O. Box 493

GARDEN CITY, KANSAS 67846

J E Jury  
Gray County

4-3-73

N - 7      SE 1/4 - 30 - 26 - 29  
Straight West of Pivot #6

0	10	Top Soil
10	17	Fine Sand
37	50	Fine to Medium Sand
50	65	Fine to Medium Sand and Gravel 20% Brown Clay (Hard)
65	82	Fine to Medium Sand and Gravel (Hard)
82	110	Brown Sandy Clay
110	126	Fine to Medium Sand and 6% Gravel (Hard)
126	145	Brown Sandy Clay with Rock Mixed
145	155	Fine to Medium Sand and Gravel (Loose)
155	185	Brown Sandy Clay
185	200	Fine to Medium Sand and Gravel (Hard)
200	215	Fine to Medium Sand and Gravel (Loose)
215	218	Yellow Clay
218	227	Shale