

## WATER WELL RECORD

Form WWC-5

KSA 82a-1212

1 LOCATION OF WATER WELL		Fraction NW 1/4 NW 1/4 NW 1/4				Section Number 32	Township Number T 26 S	Range Number R 29 E/W			
County: Gray		Distance and direction from nearest town or city? 6 miles South and 4 miles West of Ingalls, Kansas				Street address of well if located within city?					
2 WATER WELL OWNER: Charles Wendel						Board of Agriculture, Division of Water Resources					
RR#, St. Address, Box #						Application Number:					
City, State, ZIP Code		Ingalls, Kansas 67853									
3 DEPTH OF COMPLETED WELL		225 ft. Bore Hole Diameter				8 in. to 225	ft., and ..... in. to ..... ft.				
Well Water to be used as:		5 Public water supply				8 Air conditioning	11 Injection well				
1 Domestic	3 Feedlot	6 Oil field water supply	9 Dewatering	12 Other (Specify below)							
2 Irrigation	4 Industrial	7 Lawn and garden only	10 Observation well								
Well's static water level		77 ft. below land surface measured on				June	month	5th day 1979 year			
Pump Test Data		Well water was 80 ft. after 1 hour pumping.				30	gpm				
Est. Yield		Well water was ft. after hours pumping				hours pumping	gpm				
4 TYPE OF BLANK CASING USED:		5 Wrought iron		8 Concrete tile		Casing Joints: Glued XXX. Clamped .....					
1 Steel	3 RMP (SR)	6 Asbestos-Cement		9 Other (specify below)		Welded .....					
2 PVC	4 ABS	7 Fiberglass				Threaded .....					
Blank casing dia		5 in. to 225 ft. Dia			in. to ft. Dia		in. to ft.				
Casing height above land surface		12 in., weight			lbs./ft. Wall thickness or gauge No 200						
TYPE OF SCREEN OR PERFORATION MATERIAL:		7 PVC		10 Asbestos-cement							
1 Steel	3 Stainless steel	5 Fiberglass		8 RMP (SR)		11 Other (specify) .....					
2 Brass	4 Galvanized steel	6 Concrete tile		9 ABS		12 None used (open hole) .....					
Screen or Perforation Openings Are:		5 Gauzed wrapped		8 Saw cut		11 None (open hole) .....					
1 Continuous slot	3 Mill slot	6 Wire wrapped		9 Drilled holes							
2 Louvered shutter	4 Key punched	7 Torch cut		10 Other (specify) .....							
Screen-Perforation Dia		1/8 in. to 20 ft. Dia			in. to ft. Dia		in. to ft.				
Screen-Perforated Intervals:		From 200 ft. to 220 ft.			ft. From		ft. to				
Gravel Pack Intervals:		From 165 ft. to 225 ft.			ft. From		ft. to				
5 GROUT MATERIAL:		1 Neat cement	2 Cement grout	3 Bentonite	4 Other .....						
Grouted Intervals:		From 10 ft. to 20 ft.	From 150 ft. to 165 ft.	From	ft. to ft. From	ft. to ft.					
What is the nearest source of possible contamination:		10 Fuel storage		14 Abandoned water well							
1 Septic tank	4 Cess pool	11 Fertilizer storage		15 Oil well/Gas well							
2 Sewer lines	5 Seepage pit	12 Insecticide storage		16 Other (specify below)							
3 Lateral lines	6 Pit privy	9 Livestock pens		13 Watertight sewer lines							
Direction from well		Southwest		How many feet		60	? Water Well Disinfected? Yes XXX. No .....				
Was a chemical/bacteriological sample submitted to Department?		Yes .....		No XXX		If yes, date sample					
was submitted		month day		year		Pump Installed? Yes XX. No .....					
If Yes: Pump Manufacturer's name		Flint & Walling		Model No.		10BK9	HP	1 Volts 230			
Depth of Pump Intake		147 ft.	Pumps Capacity rated at		19	gal/min.					
Type of pump:		1 Submersible	2 Turbine	3 Jet	4 Centrifugal	5 Reciprocating	6 Other				
6 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION:		This water well was (1) <u>constructed</u> , (2) <u>reconstructed</u> , or (3) <u>plugged</u> under my jurisdiction and was completed on									
		June month 5th day 1979 year									
		and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 1979 179									
		This Water Well Record was completed on August month 22nd day 1979 year under the business name of JOE'S WELL SERVICE - CIMARRON, KS. by (signature) <i>Larry Crick</i>									
7 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:		FROM	TO	LITHOLOGIC LOG			FROM	TO	LITHOLOGIC LOG		
		0	15	Top soil & fine sand							
		15	45	Fine sand							
		45	60	Fine sand to medium sand & clay (4ft.)							
		60	105	Medium to coarse sand							
		105	150	Medium to coarse sand & clay layers							
		150	180	Clay							
		180	195	Clay (2ft.) & coarse sand							
		195	210	Coarse sand							
		210	225	Coarse sand & clay (2ft.)							
		225	230	Clay & blue shale							
ELEVATION:											
Depth(s) Groundwater Encountered		1 ft.	2 ft.	3 ft.	4 ft.	(Use a second sheet if needed)					
INSTRUCTIONS: Use typewriter or ball point pen, please press firmly and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Water Well Contractors, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.											