

## WATER WELL RECORD

Form WWC-5

KSA 82a-1212

1 LOCATION OF WATER WELL		Fraction SE $\frac{1}{4}$ SE $\frac{1}{4}$ NE $\frac{1}{4}$			Section Number 34	Township Number T 26 S	Range Number R 29 E/W		
County: Gray		Distance and direction from nearest town or city? 5 miles South of Ingalls, Kansas 67853 on black top road			Street address of well if located within city?				
2 WATER WELL OWNER:		John Wendell			Board of Agriculture, Division of Water Resources Application Number:				
RR#, St. Address, Box #:		Ingalls, Kansas 67853							
City, State, ZIP Code:									
3 DEPTH OF COMPLETED WELL		225 ft. Bore Hole Diameter 8 in. to			ft. and in. to ft.				
Well Water to be used as:		5 Public water supply 8 Air conditioning 11 Injection well			12 Other (Specify below)				
1 Domestic 3 Feedlot		6 Oil field water supply 9 Dewatering							
2 Irrigation 4 Industrial		7 Lawn and garden only 10 Observation well							
Well's static water level		74 ft. below land surface measured on Sept. month 27 day 1979 year							
Pump Test Data		Well water was ft. after hours pumping gpm			Well water was ft. after hours pumping gpm				
Est. Yield 50 gpm:									
4 TYPE OF BLANK CASING USED:		5 Wrought iron 8 Concrete tile Casing Joints: Glued XX Clamped			Welded				
1 Steel 3 RMP (SR)		6 Asbestos-Cement 9 Other (specify below)			Threaded				
2 PVC 4 ABS		7 Fiberglass							
Blank casing dia 5 in. to 225 ft. Dia		in. to ft. Dia in. to ft.							
Casing height above land surface 12 in., weight					lbs./ft. Wall thickness or gauge No 200 Jet Stream				
TYPE OF SCREEN OR PERFORATION MATERIAL:		7 PVC 10 Asbestos-cement							
1 Steel 3 Stainless steel 5 Fiberglass 8 RMP (SR) 11 Other (specify)		6 Concrete tile 9 ABS 12 None used (open hole)							
2 Brass 4 Galvanized steel		5 Gauzed wrapped 8 Saw cut 11 None (open hole)							
Screen or Perforation Openings Are:		6 Wire wrapped 9 Drilled holes							
1 Continuous slot 3 Mill slot 4 Key punched		7 Torch cut 10 Other (specify)							
Screen-Perforation Dia. 1/8 in. to 20 ft. Dia		in. to ft. Dia in. to ft.							
Screen-Perforated Intervals: From 200 ft. to 220 ft.		ft., From ft. to ft.							
From 100 ft. to 120 ft.		ft., From ft. to ft.							
Gravel Pack Intervals: From 150 ft. to 225 ft.		ft., From ft. to ft.							
5 GROUT MATERIAL: 1 Neat cement 2 Cement grout 3 Bentonite 4 Other									
Grouted Intervals: From 120 ft. to 135 ft. From ft. to ft. From ft. to ft. From ft. to ft.									
What is the nearest source of possible contamination:									
1 Septic tank 4 Cess pool 7 Sewage lagoon 10 Fuel storage 14 Abandoned water well									
2 Sewer lines 5 Seepage pit 8 Feed yard 11 Fertilizer storage 15 Oil well/Gas well									
3 Lateral lines 6 Pit privy 9 Livestock pens 12 Insecticide storage 16 Other (specify below)									
Direction from well East How many feet 125 ? Water Well Disinfected? Yes XX No									
Was a chemical/bacteriological sample submitted to Department? Yes No If yes, date sample									
was submitted month day year Pump Installed? Yes XXX No									
If Yes: Pump Manufacturer's name Flint & Walling Model No. 10BK9 HP 1 Volts 230									
Depth of Pump Intake 150 ft. Pumps Capacity rated at 19 gal./min.									
Type of pump: 1 Submersible 2 Turbine 3 Jet 4 Centrifugal 5 Reciprocating 6 Other									
6 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on Sept. month 27 day 1979 year									
and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 179									
This Water Well Record was completed on Nov. month 15 day 1979 year under the business name of JOE'S WELL SERVICE - CIMARRON, KS. 67835 by (signature) <i>Larry Crick</i>									
7 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:		FROM	TO	LITHOLOGIC LOG		FROM	TO	LITHOLOGIC LOG	
		0	15	Top soil & clay		210	225	Coarse sand, clay, rock layers & blue shale	
		15	30	Clay & fine sand					
		30	45	Fine sand					
		45	60	Fine to medium sand & clay					
		60	75	Clay & medium to coarse sand					
		75	90	Coarse sand					
		90	105	Coarse sand & clay					
		105	150	Clay					
		150	165	Clay & fine sand					
		165	180	Fine to medium sand					
		180	210	Medium to coarse sand					
ELEVATION:									
Depth(s) Groundwater Encountered 1 ft. 2 ft. 3 ft. 4 ft. (Use a second sheet if needed)									
INSTRUCTIONS: Use typewriter or ball point pen, please press firmly and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Water Well Contractors, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.									