


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County	Fraction	Section number	Township number	Range number	
	Gray	SE 1/4 Nw 1/4 Nw 1/4	36	T 26	S R 29 E 0	
2. Distance and direction from nearest town or city:	3. Owner of well:		Richard Batman			
Street address of well location if in city:			Ingalls, Kansas			
4. Locate with "X" in section below:	Sketch map:		28 Well depth 224 ft. 8-9-77			
			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary			
5. Type and color of material	From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
Surface	0	3	9. Casing: Material <input checked="" type="checkbox"/> Metal Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 10 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 31.66 lbs./ft. Dia. 16 in. to 224 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gauge No. 188			
Fine sand	3	8	10. Screen: Manufacturer's name <input checked="" type="checkbox"/> W.A. Brown Type 10% Free-flo. 16 Slot/gauze 1/8 Length 160 Set between 64 ft. and 224 ft. Gravel pack? <input checked="" type="checkbox"/> Yes Size range of material 3/8 down CMA			
Brown clay	8	68	11. Static water level: <input type="checkbox"/> 70 ft. below land surface Date 3-19-77			
Good loose sand and gravel	68	96	12. Pumping level below land surfaces: 90 ft. after 1 hrs. pumping 1000 g.p.m. 95 ft. after 1 hrs. pumping 1400 g.p.m. Estimated maximum yield 2500 g.p.m.			
half med. to good med. sand and gravel	96	125	13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date			
Sandy brown clay	125	133	14. Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade			
50% fine sand mixed with clay	133	147	15. Well grouted? <input type="checkbox"/> no With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <input type="checkbox"/> ft. to <input type="checkbox"/> ft.			
Sandy brown clay	147	155	16. Nearest source of possible contamination: <input type="checkbox"/> field ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input checked="" type="checkbox"/> field Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
Good loose half med. sand and gravel	155	178	17. Pump: <input type="checkbox"/> Not installed Manufacturer's name <input checked="" type="checkbox"/> Goulds Model number 12JMO HP 100 Volts Length of drop pipe 160 ft. capacity 900 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
Brown clay	178	185				
Fine sand with 20% brown clay mixed	185	193				
Brown clay with coleche mixed	193	207				
Med. sand and gravel	207	221				
Yellow clay	221	241				
Blue shale	241	255				
(Use a second sheet if needed)						
18. Elevation:	19. Remarks: 10' of groute and pump slab to be installed by the customer-he knows this is a regulation					20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Richard Batman 190 Business name Ace-Hi International Address Dodge City, Ks Signed <input checked="" type="checkbox"/> Gail Goutzah Date 9-6- Authorized representative
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						