


AS-3

1 LOCATION OF WATER WELL: County: Sedgwick		Fraction: SW $\frac{1}{4}$ NE $\frac{1}{4}$ NE $\frac{1}{4}$	Section Number: 15	Township Number: T 26 S	Range Number: R 3 E																																																						
Distance and direction from nearest town or city street address of well if located within city? Andale Yard, 248 S. Main Street, Andale, Ks																																																											
2 WATER WELL OWNER: RR#, St. Address, Box # : Sedgwick County Attn: Allison McKinney Brown City, State, ZIP Code : 525 N. Main, Suite 539, Wichita, Ks 67203 Board of Agriculture, Division of Water Resources Application Number: -----																																																											
3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX: 		4 DEPTH OF COMPLETED WELL: 55 ft. ELEVATION: ----- Depth(s) Groundwater Encountered 1. 44.5 ft. 2. ----- ft. 3. ----- ft. WELL'S STATIC WATER LEVEL ----- ft. below land surface measured on mo/day/yr Pump test data: Well water was ----- ft. after ----- hours pumping ----- gpm Est. Yield ----- gpm: Well water was ----- ft. after ----- hours pumping ----- gpm Bore Hole Diameter 8.625 in. to ----- in. and ----- in. to ----- in. WELL WATER TO BE USED AS: 1 Domestic 2 Irrigation 3 Feedlot 4 Industrial 6 Oil field water supply 7 Lawn and garden only 8 Air conditioning 10 Monitoring well AS-3 11 Injection well 12 Other (Specify below) Was a chemical/bacteriological sample submitted to Department? Yes ----- No X ; If yes, mo/day/yr sample was submitted ----- Water Well Disinfected? Yes ----- No X																																																									
5 TYPE OF BLANK CASING USED: 1 Steel 2 PVC Blank casing diameter 2 in. to 52.5 ft., Dia ----- in. to ----- ft., Dia ----- in. to ----- ft. Casing height above land surface 0 in., weight SCH 40 PVC lbs./ft. Wall thickness or gauge No. ----- 3 RMP (SR) 4 ABS 5 Wrought iron 6 Asbestos-Cement 7 Fiberglass 8 Concrete tile 9 Other (specify below) CASING JOINTS: Glued ----- Clamped ----- Welded ----- Threaded X TYPE OF SCREEN OR PERFORATION MATERIAL: 1 Steel 2 Brass SCREEN OR PERFORATION OPENINGS ARE: 1 Continuous slot 2 Louvered shutter 3 Stainless steel 4 Galvanized steel 3 Mill slot 4 Key punched 5 Fiberglass 6 Concrete tile 5 Gauzed wrapped 6 Wire wrapped 7 Torch cut 8 RMP (SR) 9 ABS 8 Saw cut 9 Drilled holes 10 Other (specify) 10 Asbestos-cement 11 Other (specify) 12 None used (open hole) 11 None (open hole) SCREEN-PERFORATED INTERVALS: From 52.5 ft. to 55 ft., From ----- ft. to ----- ft., From ----- ft. to ----- ft. SAND GRAVEL PACK INTERVALS: From 51.5 ft. to 55 ft., From ----- ft. to ----- ft., From ----- ft. to ----- ft.																																																											
6 GROUT MATERIAL: Grout Intervals: From 0 ft. to 49.5 ft., From 49.5 ft. to 51.5 ft., From ----- ft. to ----- ft. What is the nearest source of possible contamination: 1 Septic tank 2 Sewer lines 3 Watertight sewer lines 4 Lateral lines 5 Cess pool 6 Seepage pit 7 Pit privy 8 Sewage lagoon 9 Feedyard 10 Livestock pens 11 Fuel storage 12 Fertilizer storage 13 Insecticide storage 14 Abandoned water well 15 Oil well/Gas well 16 Other (specify below) Contaminated Si Direction from well? ----- How many feet? -----																																																											
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>FROM</th> <th>TO</th> <th>LITHOLOGIC LOG</th> <th>FROM</th> <th>TO</th> <th>PLUGGING INTERVALS</th> </tr> </thead> <tbody> <tr> <td>GL</td> <td>2.00</td> <td>Fill</td> <td></td> <td></td> <td></td> </tr> <tr> <td>2.00</td> <td>5.00</td> <td>Clayey Silt (ML)</td> <td></td> <td></td> <td></td> </tr> <tr> <td>5.00</td> <td>30.50</td> <td>Silty Clay (CL)</td> <td></td> <td></td> <td></td> </tr> <tr> <td>30.50</td> <td>34.50</td> <td>Clayey Silt (ML)</td> <td></td> <td></td> <td></td> </tr> <tr> <td>34.50</td> <td>38.00</td> <td>Silty Sand (SM)</td> <td></td> <td></td> <td></td> </tr> <tr> <td>38.00</td> <td>54.50</td> <td>Sand (SP)</td> <td></td> <td></td> <td></td> </tr> <tr> <td>54.50</td> <td>55.00</td> <td>Shale</td> <td></td> <td></td> <td></td> </tr> <tr> <td>55.00</td> <td>TD</td> <td>End of Borehole</td> <td></td> <td></td> <td></td> </tr> </tbody> </table> Flush Mount waiver D. Taylor 4/31/97						FROM	TO	LITHOLOGIC LOG	FROM	TO	PLUGGING INTERVALS	GL	2.00	Fill				2.00	5.00	Clayey Silt (ML)				5.00	30.50	Silty Clay (CL)				30.50	34.50	Clayey Silt (ML)				34.50	38.00	Silty Sand (SM)				38.00	54.50	Sand (SP)				54.50	55.00	Shale				55.00	TD	End of Borehole			
FROM	TO	LITHOLOGIC LOG	FROM	TO	PLUGGING INTERVALS																																																						
GL	2.00	Fill																																																									
2.00	5.00	Clayey Silt (ML)																																																									
5.00	30.50	Silty Clay (CL)																																																									
30.50	34.50	Clayey Silt (ML)																																																									
34.50	38.00	Silty Sand (SM)																																																									
38.00	54.50	Sand (SP)																																																									
54.50	55.00	Shale																																																									
55.00	TD	End of Borehole																																																									
7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed (2) reconstructed, or (3) plugged under my jurisdiction and was completed on (mo/day/year) 2-19-97 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 585 This Water Well Record was completed on (mo/day/yr) 4-5-97 under the business name of ACT by (signature) D. Taylor																																																											