

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

Location of well:	County Gray County	Fraction NE 1/4 SE 1/4 NE 1/4	Section number 1	Township number T 26 S R 30	Range number E/W
2. Distance and direction from nearest town or city: 1 East of Charleston	Owner of well: Don Renick				
on Hiway 50, 2 1/2 South, 1/2 East	R.R. or street: Ingalls, KS 67853				
Street address of well location if in city:					
4. Locate with "X" in section below:					
Sketch map:					
6. Bore hole dia. 26 in. Completion date 12-29-78					
Well depth 236 ft.					
7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary					
8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other					
9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 1 ft. in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia 16 in. to 236 ft. depth Wall Thickness: inches or Dia. 16 in. to 236 ft. depth Gauge No. .219					
10. Screen: Manufacturer's name Johnson					
Type Johnson Screen 100-16" Slot/gauze 0-100 Plain 100-120 Perf. Set between 120-130 Screen 130-140 Perf. 140-213 Perf. 213-236 Perf. ft. Gravel pack? yes Size range of material 1/2 to 5/8					
11. Static water level: mo./day/yr. 70 ft. below land surface Date 10-31-78					
12. Pumping level below land surfaces: 101 ft. after 2 hrs. pumping 1250 g.p.m. 111 ft. after 4 hrs. pumping 1700 g.p.m. Estimated maximum yield 1700 g.p.m.					
13. Water sample submitted: mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____					
14. Well head completion: <input type="checkbox"/> Pitless adapter 1 ft. Inches above grade					
15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.					
16. Nearest source of possible contamination: ft. Direction N/A Type _____ Well disinfected upon completion? Yes <input checked="" type="checkbox"/> No					
17. Pump: Not installed Manufacturer's name Could 4 stg. 12" Bowl Model number _____ HP _____ Volts _____ Length of drop pipe 140 ft. capacity 1000 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other					
18. Elevation: 19. Remarks:					
<p>(Use a second sheet if needed)</p> <p>Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley</p>					
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drilling Co. 208 Business name _____ License No. _____ Address Box A, Garden City, KS 67853 Signed John Minter Date 10-29-78 Authorized representative _____					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

1978-12-10 D.O. Box A - GARDEN CITY, IDAHO 83421
September 13, 1978

Don Renick
Gray County

Location: N. E. 1/4 1-26-30 30 feet East of Pivot

Static Water Level

Test #2

0	1	Top Soil
1	32	Fine Sand
32	42	Brown Clay
42	49	Med. Coarse Gravel (loose)
49	89	Brown Sandy Clay
89	101	Fine to med. sand and gravel
101	107	Brown Clay
107	132	Fine to med. sand and gravel White Rock mixed Loose
132	140	Brown Sandy Clay
140	153	Fine to med. Sand and gravel (loose)
153	171	Brownish Clay
171	179	Fine to med. Sand and fine Gravel (loose)
179	213	Brown Clay
213	234	Fine to med. sand and gravel mixed with yellow Rock (loose)
234	237	Yellow Clay
237	239	Shale (hard)

T. D. 236