


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County <u>GRAY</u>	Fraction <u>NE SW</u> <u>1/4</u> <u>1/4</u> <u>1/4</u> <u>1/4</u>	Section number <u>3</u>	Township number <u>T 26 S</u>	Range number <u>R 30 E/W</u>
2. Distance and direction from nearest town or city: <u>south of Pierceville, Mo.</u>				Owner of well: <u>LONNIE WARTMAN</u>		
Street address of well location if in city: <u>4 east 1/4 north 1/4 east</u>				R.R. or street: <u>INGALLS, KS. 67853</u>		
City, state, zip code:						
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>26</u> in. Completion date <u>5-31-76</u> Well depth <u>270</u> ft.		
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
5. Type and color of material		From		To		8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
						9. Casing: Material <u>Steel</u> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>36</u> <u>12</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>36.87</u> lbs./ft. Dia. <u>16</u> in. to <u>271</u> ft. depth Wall Thickness: inches or Dia. <u> </u> in. to <u> </u> ft. depth gage No. <u> </u>
						10. Screen: Manufacturer's name <u>n Johnson Division</u> Type <u>Galv</u> Dia. <u>16"</u> Slot/gauze <u>100</u> Length <u>20'</u> Set between <u>160-170</u> ft. and <u>230-240</u> ft. Perf. <u>100-160</u> ft. and <u>170-230, 240-270</u> ft. Gravel pack? <u>yes</u> Size range of material <u>1/2" Down</u>
						11. Static water level: <u>81</u> ft. below land surface Date <u>4-27-76</u> mo./day/yr.
						12. Pumping level below land surfaces: <u>89</u> ft. after <u>3</u> hrs. pumping <u>1450</u> g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u>1450</u> g.p.m.
						13. Water sample submitted: <u> </u> mo./day/yr. <u> </u> Yes <u> </u> No Date <u> </u>
						14. Well head completion: <u> </u> Pitless adapter <u>12</u> inches above grade
						15. Well grouted? <u>yes</u> With: <u> </u> Neat cement <u> </u> Bentonite <u> </u> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.
						16. Nearest source of possible contamination: <u>N/A</u> ft. <u> </u> Direction <u> </u> Type <u> </u> Well disinfected upon completion? <u> </u> Yes <u> </u> No
						17. Pump: <u>Not installed</u> Manufacturer's name <u>Goulds US Pumps</u> Model number <u>12 JHO</u> HP <u> </u> Volts <u> </u> Length of drop pipe <u>140</u> ft. capacity <u>1000</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		Customer furnished electric motor Drilling done by Central well and pump Pratt, Ks		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Minter Wilson Drilling 208</u> Business name <u>P.O. Box A Garden City, Ks.</u> License No. <u> </u> Address <u> </u> Signed <u> </u> Date <u>7-16-76</u> Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

The Professionals

MINTER-WILSON DRILLING CO.
INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

HUSBAND RIG
LONNIE WARTMAN
GRAY COUNTY
3-25-76

LOCATION: SW $\frac{1}{4}$ 3-26-30
25' West Of Pivot

DEPTH: 275'
STATIC WATER LEVEL: 60'

TEST #1

0	30	Soil, Sand & Clay
30	60	Clay & Fine Sand
60	73	Fine To Med. Sand & Gravel
73	173	Fine To Med. Sand & Gravel (Coarse)
173	177	Clay
177	190	Fine To Med. Sand & Gravel (10%)
190	192	Rock (Hard)
192	199	Fine To Med. Sand & Gravel
199	230	Clay & Sand Streak (No Good)
230	245	Fine To Med. Sand & Gravel
245	254	Clay & Sand Streak (Tight)
254	270	Fine To Med. Sand & Gravel With Little Streak Of Rock
270	275	Clay, Yellow & Blue Shale