


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Gray	Township name Ingalls	Fraction Pivot NE $\frac{1}{4}$	Section number 5	Town number T 26 S	Range number R 30 W
Distance and direction from nearest town or city: 3 $\frac{1}{2}$ south, 3 west 3 $\frac{1}{4}$ north, $\frac{1}{4}$ west of Charleston, Ks. Street address of well location if in city:			3 Owner of well: Don Renick Address: Ingalls, Ks. 67853			
Locate with "X" in section below: N 			Sketch map: #49			
<p>4 Well depth: <u>288</u> ft. Date of completion <u>3-19-75</u> Well diameter <u>26</u> in.</p> <p>5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary</p> <p>6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well</p> <p>7 Casing: Material <u>Steel</u> Height: above/below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. Diam. <u>16</u> in. to <u>289</u> ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No in. to <u>16</u> ft. depth</p> <p>8 Screen: Manufacturer <u>Johnson Division</u> Type <u>Galv.</u> Dia. <u>16"</u> Slot/gauge _____ Length <u>20'</u> Set between <u>240</u> ft. and <u>260</u> ft.</p> <p>9 Static water level: <u>50</u> ft. below land surface Date <u>2-1-75</u></p> <p>10 Pumping level below land surfaces: <u>66</u> ft. after <u>2</u> hrs. pumping <u>805</u> g.p.m. <u>77</u> ft. after <u>4</u> hrs. pumping <u>1245</u> g.p.m. Estimated maximum yield <u>1200</u> g.p.m.</p> <p>11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____</p> <p>12 Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade</p> <p>13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> _____ Depth: From <u>0</u> ft. to <u>10</u> ft.</p> <p>14 Nearest source of possible contamination: <u>N/A</u> ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No</p> <p>15 Pump: <input type="checkbox"/> Not installed Manufacturer's name <u>Peerless-FMC</u> Model number <u>4465</u> HP _____ Volts _____ Length of drop pipe <u>160</u> ft. capacity <u>1200</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other</p> <p>16 Remarks: elevation Surrounded by other fields, Good well. Electric motor installed.</p> <p>Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley</p> <p>17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drilling Co. 208 Business name <u>Box 493 Garden City, Ks.</u> License No. _____ Address <u>Box 493 Garden City, Ks.</u> _____ Date <u>2-20-75</u> Authorized representative <u>John Minter</u></p>						

Forward the white, blue and pink copies to the Kansas State Dept. of Health.

Form WWC-5

Professional MINTER-WILSON DRILLING CO. INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-3269 . P.O. Box 493 . GARDEN CITY, KANSAS 67846

Don Renick

1-10-75

Location: South of Charleston to Plymell
Road, 3 miles west, 3/4 North, 1/4 West

Test: #1

0	23	Fine to med. sand
	35	Fine to med. sand & clay
	48	Brown clay
	115	Fine to med. sand & gravel (loose)
	125	Brown clay
	125	Fine to med. sand & gravel (loose)
	158	Brown sandy clay
	169	Fine to med. sand & gravel, 10% clay (loose)
	174	Brown clay & white rock (tight)
	185	Brown clay
	227	Fine to med. sand & gravel, 10% clay (loose)
	245	Fine to med. sand & gravel (loose)
	260	Brown sandy clay, small streaks of gravel, 30% (loose)
	275	Fine to med. sand & gravel, 15% clay & white rock (fairly loose)
	288	Yellow clay & shale (Hard)