


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

Gray county

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County <u>Gray Co.</u> Platte	Fraction <u>SE 1/4 NW 1/4 SE 1/4</u>	Section number <u>5</u>	Township number <u>T 26 S R 30 E W</u>	Range number <u>30</u>
2. Distance and direction from nearest town or city: <u>4 south, 3 1/2 west, 1/2 north of Charleston.</u> Street address of well location if in city:				3. Owner of well: <u>Don Renick (#66)</u> R.R. or street: City, state, zip code: <u>Ingalls, Ks. 67853</u>		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>26</u> in. Completion date <u>6-28-77</u> Well depth <u>302</u> ft.		
				7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material <u>steel</u> Height: Above <u>surface</u> Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>36.87</u> lbs./ft. Dia. <u>16</u> in. to <u>303</u> ft. depth Wall Thickness: <u>inches</u> or Dia. <u>in.</u> to <u>ft.</u> depth gage No. <u>250</u>		
				10. Screen: Manufacturer's name <u>Johnson</u> Type <u>galv.</u> Dia. <u>16"</u> Slot <u>5/16"</u> Length <u>10 ft.</u> Set between <u>210-220</u> ft. and <u>280-290</u> ft. Perf: <u>110-210</u> ft. and <u>220-280, 290-302</u> Gravel pack? <u>yes</u> Size range of material <u>1/4" down</u>		
				11. Static water level: <u>117</u> ft. below land surface Date <u>5-10-77</u>		
				12. Pumping level below land surfaces: <u>121</u> ft. after <u>2</u> hrs. pumping <u>900</u> g.p.m. <u>126</u> ft. after <u>4</u> hrs. pumping <u>1500</u> g.p.m. Estimated maximum yield <u>1500</u> g.p.m.		
				13. Water sample submitted: <u>mo./day/yr.</u> <u>Yes</u> <input checked="" type="checkbox"/> <u>No</u> Date <u>5-10-77</u>		
				14. Well head completion: <u>Pitless adapter</u> <u>12</u> Inches above grade		
				15. Well grouted? <u>Yes</u> With: <u>Neat cement</u> <u>Bentonite</u> <input checked="" type="checkbox"/> <u>Concrete</u> Depth: From <u>0</u> ft. to <u>10</u> ft.		
				16. Nearest source of possible contamination: <u>N/A</u> ft. <u>Direction</u> <u>Type</u> Well disinfected upon completion? <u>Yes</u> <input checked="" type="checkbox"/> <u>No</u>		
				17. Pump: Manufacturer's name <u>Goulds-US Pump</u> Not installed Model number <u>12JLMO</u> HP <u>60</u> Volts <u>1500</u> Length of drop pipe <u>160</u> ft. capacity <u>1500</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Minter-Wilson Drilling Co. 208</u> Business name <u>Box A Garden City, Ks.</u> License No. <u>1/4 SE NW SE</u> Address <u>Box A Garden City, Ks.</u> Signed <u>Gene L. Minter</u> Date <u>11-28-77</u> Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5