


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:	County <b>Gray County</b>	Fraction 1/4 1/4 <b>NW 1/4</b>	Section number <b>6</b>	Township number <b>T 26 S</b>	Range number <b>R 30 E</b>
2. Distance and direction from nearest town or city: <b>2 1/2 South of Charleston</b>	of well: <b>4 1/2 West, 1/2 South</b>	R.R. or street: <b>Pierceville, KS 67868</b>	Anna Johnson (Owner) Bob Husband (Tenant)		
Street address of well location if in city:					
4. Locate with "X" in section below:	Sketch map:			6. Bore hole dia. <b>26</b> in. Completion date <b>3-21-77</b> Well depth <b>260</b> ft.	
			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material <b>Steel</b> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>1 ft.</b> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <b>36.87</b> lbs./ft. Dia <b>16</b> in. to <b>260</b> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <b>.219</b>		
5. Type and color of material			From	To	10. Screen: Manufacturer's name <b>Johnson</b> Type <b>Johnson Galv. Di. 100-16"</b> Slot/gauge <b>0-100 Plain</b> <b>100-200 Perf.</b> Set between <b>200-235 Plain</b> <b>235-255 f Screen</b> <b>255-260 Perf.</b> <b>ft.</b> Gravel pack? <b>yes</b> Size range of material <b>1 to 5/8</b>
					11. Static water level: <b>80</b> ft. below land surface Date <b>80</b>
					12. Pumping level below land surfaces: <b>73</b> ft. after <b>2</b> hrs. pumping <b>600</b> g.p.m. <b>79</b> ft. after <b>4</b> hrs. pumping <b>1200</b> g.p.m. Estimated maximum yield <b>1200</b> g.p.m.
					13. Water sample submitted: Yes <input checked="" type="checkbox"/> No Date <b>1 ft.</b> Inches above grade
					14. Well head completion: <input type="checkbox"/> Pitless adapter <b>1 ft.</b> Inches above grade
					15. Well grouted? <b>yes</b> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <b>0</b> ft. to <b>10</b> ft.
					16. Nearest source of possible contamination: ft. <b>0</b> Direction <b>N/A</b> Type <b>0</b> Well disinfected upon completion? Yes <b>0</b> No <b>0</b>
					17. Pump: <b>Not installed</b> Manufacturer's name <b>Gould 5 stg. 12" Bowl</b> Model number <b>100</b> HP <b>100</b> Volts <b>1000</b> g.p.m. Length of drop pipe <b>160</b> ft. capacity <b>1000</b> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
(Use a second sheet if needed)					18. Elevation: Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley
19. Remarks:			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Minter Wilson Drilling Co. 208</b> Business name <b>Box A, Garden City, KS 67846</b> License No. <b>437779</b> Address <b>Box A, Garden City, KS 67846</b> Date <b>4/14/81</b> Signature <b>Minter Wilson</b> <b>4/14/81</b> <b>4/14/81</b> <b>4/14/81</b> Authorized representative <b>4/14/81</b>		

**WILSON DRILLING CO.** INCORPORATED

Irrigation  
and Domestic  
Water Systems  
Complete Installation  
and Repairing

Phone 276-8269 . P.O. Box A . GARDEN CITY, KANSAS 67846

December 1, 1978

Anne Johnson - Owner  
Bob Husband - Tenant  
Gray County

Location: N. W. 1/4 6-26-30. Piercerville and Plymell Jet. 2  
mile East, 1/2 mile North, 1320' East 1320 North,  
35 North West of Pivot

Subsoil Water Level - 80

Test #

0	10	Top Soil (fine)
10	53	Fine Sand Clay mixed
53	65	Fine to med. sand and gravel
65	112	Coarse Gravel (loose)
112	145	Fine to med. sand and gravel streak of coarse Gravel (loose)
145	149	Brown Clay small streak of coarse gravel
149	156	Brown Clay
156	168	Fine to med. sand and gravel streak of coarse Gravel (loose)
168	194	Fine to med. sand and gravel Clay streak mixed (loose)
194	200	Fine to med. sand and fine gravel clay mixed (tight)
200	215	Fine sand Clay streak mixed (loose)
215	219	Fine to med. Sand (loose)
219	238	Brown Sandy Clay
238	255	Fine to med. sand and fine gravel mixed small 20% White Rock Tight
255	267	Yellow Clay hard pull down
267	272	Shale hard pull down