


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Gray	Fraction NW 1/4 NE 1/4 SE 1/4	Section number 7	Township number T 26 S	Range number R 30 E (W)
2. Distance and direction from nearest town or city: 3 1/2 S. and 3 E. of Pierceville Street address of well location if in city:			3. Owner of well: Clyde Priddle R.R. or street: 1609 Coolidge St. City, state, zip code: Wichita, KS		
4. Locate with "X" in section below: N	Sketch map: 		Well drilled 3-12-76		6. Bore hole dia. 26 in. Completion date 3-17-76 Well depth 29 ft.
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input checked="" type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
				9. Casing: Material <input type="checkbox"/> Steel <input checked="" type="checkbox"/> Iron <input type="checkbox"/> Copper Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 31 lbs./ft. Dia 16 in. to 29 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. .188	
5. Type and color of material See attachment		From	To	10. Screen: Manufacturer's name Brown Type <input type="checkbox"/> Louvered <input checked="" type="checkbox"/> Slotted Dia. 16" Slot/gauze 1/8" Length 130' Set between 160 ft. and 290 ft. ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> Yes Size range of material $\frac{1}{4}$ x 1/8	
				11. Static water level: mo./day/yr. 63 ft. below land surface Date 3-17-76	
				12. Pumping level below land surfaces: 150 ft. after <input type="checkbox"/> hrs. pumping 2,000 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <input type="checkbox"/> g.p.m.	
				13. Water sample submitted: mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date	
				14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade	
				15. Well grouted? <input checked="" type="checkbox"/> Yes With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
				16. Nearest source of possible contamination: ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Observed Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)				18. Elevation: Flat Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	
19. Remarks:				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Henkle Drilling & Supply 145 Business name <input type="checkbox"/> License No. <input type="checkbox"/> Address Box 639, Garden City, KS Signed <input type="checkbox"/> Date 3-7-76 Authorized representative	

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

DRILLERS TEST LOG

CUSTOMERS NAME Mr. Clyde Priddle DATE 3-3-76
 STREET ADDRESS 1609 Coolidge Street TEST # 1 E. Log 300 Ft.
 CITY & STATE Wichita, Kansas DRILLER Rector
 COUNTY Gray QUARTER SE SECTION 7 TOWNSHIP 26 RANGE 30
 LOCATION 1250 Ft. West of the NE corner of 1/4 almost in 1/2 Section line.

%	DRILLED		FOOTAGE	STATIC WATER LEVEL PROPOSED WELL DEPTH
	FROM	PAY		
	0		2	Surface
	2		17	Fine sand
	17		30	Clay and caliche
	30		85	Sand and gravel and few cobblestones
	85		104	Brown clay and caliche
50	104	19	123	Sand fine med. coarse, small gravel.
	123		130	Brown clay and caliche
55	130	6	136	Sand fine med. coarse, med., small.
	136		140	Brown sandy clay
60	140	23	163	Sand fine med. coarse, small gravel. Loose Used water.
	163		176	Brown clay and caliche
	176	34	210	Sand fine med. coarse, small gravel and small white rock and very few fine clay st. Used lots of water. Loose.
	210		225	Brown clay and sand st.
75	225	15	240	Sand fine med. coarse, small gravel and white rock, real loose. Used lots of water.
	240		260	Brown clay
70	260	15	275	Sand fine med. coarse, small gravel and small white and tan rock. Loose. Used lots of water. Very good.
	275		280	Brown clay, sticky.
	280	14	294	Limestone, cemented sand, clay
	294		300	Shale, hard.
			126	TOTAL DEPTH OF WELL 294 FT.
				Set up facing West
				Pit on the North
				Pump motor on east side of well.

HENKLE DRILLING & SUPPLY CO., INC.

GARDEN CITY, KANSAS

Phone 276-3278

TEST HOLES

DOMESTIC WELLS

STOCK WELLS

IRRIGATION & INDUSTRIAL WELLS

SUBLETTE, KANSAS

Phone 675-4311