

USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:	County	Fraction	Section number	Township number	Range number	
	Gray	NW 1/4 NW 1/4 SW 1/4	12	T 26	S R 30 E/W	
2. Distance and direction from nearest town or city:	4 miles South of Charleston on the Charleston Road		3. Owner of well:	Loren Doll		
Street address of well location if in city:			R.R. or street:			
4. Locate with "X" in section below:			Sketch map:	6. Bore hole dia.	6 5/8 in. Completion date	
				Well depth	214 ft. 11-17-78	
				7. Cable tool	XX	Rotary    Driven    Dug Hollow rod    Jetted    Bored    Reverse rotary
				8. Use:	XX Domestic    Public supply    Industry Irrigation    Air conditioning    XX Stock Lawn    Oil field water    Other	
				9. Casing: Material	RMP    Height: Above ground Threaded    Welded    Surface 12 in. RMP    XX PVC    Weight    lbs./ft. Dia. 6 5/8 in. to 214 ft. depth    Wall Thickness: inches or Dia.    in. to    ft. depth    gage No. 320	
5. Type and color of material			From	To	10. Screen: Manufacturer's name Jess & Lowell	
Top soil & clay			0	15	Type	RMP    Dia. 6 5/8"
Clay & fine sand			15	30	Slot/gauge	XX 1/8"    Length 20 ft.
Fine sand			30	60	Set between	190 ft. and 210 ft.
Fine sand & medium sand			60	75	ft. and	ft.
Medium to coarse sand			75	90	Gravel pack?	yes    Size range of material 1/16
Coarse sand			90	150	11. Static water level:	mo./day/yr. 101 ft. below land surface Date 11-17-78
Coarse sand & clay (2 ft.)			150	217	12. Pumping level below land surfaces:	ft. after    hrs. pumping    g.p.m. ft. after    hrs. pumping    g.p.m. Estimated maximum yield 90 g.p.m.
Clay			217	225	13. Water sample submitted:	mo./day/yr. Yes    XX    No    Date
					14. Well head completion:	XX Pitless adapter    12 inches above grade
					15. Well grouted?	yes With: XX Neat cement    Bentonite    Concrete Depth: From 7 ft. to 20 ft.
					16. Nearest source of possible contamination:	none ft.    Direction    Type Well disinfected upon completion? XX Yes    No
					17. Pump:	Not installed Manufacturer's name    Goulds Model number    25EL    HP 3    Volts 230 Length of drop pipe 168 ft. capacity 25 g.p.m. Type: XX Submersible    Turbine Jet    Reciprocating Centrifugal    Other
(Use a second sheet if needed)					18. Elevation:	19. Remarks:  This is a new building site
					20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Joe's Well Service 179 Business name    License No. Address    Box 174 Cimarron, Ks. Signed    Larry Crick 12-27-78 Date    12-27-78 Authorized representative	