


USE TYPEWRITER OR BALL
POINT PEN - PRESS FIRMLY
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

13. Location of well:	County: Gray	Fraction: SW 1/4 NW 1/4 SW 1/4	Section number: 14	Township number: T 26 S	Range number: R 30 E/W
2. Distance and direction from nearest town or city: 6 1/2 miles south of Charleston, Mo. 1/2 west, 1/4 north, 1/4 west		3. Owner of well: Rudy Eichenauer R.R. or street: Ingalls, Ks.			
Street address of well location if in city:					
4. Locate with "X" in section below:		Sketch map: 			
		6. Bore hole dia. 26 in. Completion date 8-1-75 Well depth 294 ft.			
		7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary			
		8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
		9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 295 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 219 MHC			
5. Type and color of material		From	To	10. Screen: Manufacturer's name Johnson Division Type Galv. Dia. 16"! Slot/gauge <input type="checkbox"/> Length 20' Set between 200-210 ft. and 280-290 ft. Perf: 100-200, 210-225, 265-280, 290 Gravel pack? <input checked="" type="checkbox"/> YES Size range of material 16" down	
				11. Static water level: mo./day/yr. 64 ft. below land surface Date 8-7-75	
				12. Pumping level below land surfaces: 76 ft. after 2 hrs. pumping 776 g.p.m. 85 ft. after 4 hrs. pumping 1222 g.p.m. Estimated maximum yield 1200 g.p.m.	
				13. Water sample submitted: mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date	
				14. Well head completion: Pitless adapter 12 Inches above grade	
				15. Well grouted? <input checked="" type="checkbox"/> YES With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
				16. Nearest source of possible contamination: N/A ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>	
				17. Pump: Not installed Manufacturer's name Peerless- FMC Model number 5154 HP 100 Volts <input type="checkbox"/> Length of drop pipe 140 ft. capacity 1200 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drilling Co. 208 Business name <input type="checkbox"/> Address Box 493 Garden City, Ks. Signed <input type="checkbox"/> Date 11-21 Authorized representative <input type="checkbox"/>	
18. Elevation:	19. Remarks:				
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

Professional MINTER-WILSON DRILLING CO. INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

RUDY EICHENAUER

Gray County

5-8-75

Location: 6 $\frac{1}{2}$ miles south of Charleston, $\frac{1}{2}$ west, $\frac{1}{2}$ north,
 $\frac{1}{4}$ west SW $\frac{1}{4}$ 14-26-30

0	2	Top soil, fine sand with dirt
2	18	Dirt
18	25	Brown sandy clay
25	43	Fine sand (loose)
43	55	Brown, white clay
55	61	Fine to med. sand and gravel (loose)
61	64	Brown sandy clay
64	70	Med. sand, coarse gravel (loose)
70	156	Med. coarse gravel (loose)
156	159	Brown sandy clay
159	174	Med. sand, coarse gravel (loose)
174	191	Brown, white clay
191	225	Fine to med. sand and gravel (good loose)
225	271	Brown sandy clay
271	29 $\frac{1}{4}$	Fine to med. sand (loose)
29 $\frac{1}{4}$	318	Brown sandy clay, streak of sand (hard)
318	32 $\frac{1}{4}$	Brown, yellow clay with rock (hard)
32 $\frac{1}{4}$	327	Shale

Static Water Level: 60'

T.D. 29 $\frac{1}{4}$ '