


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

Location

1. Location of well:	County Gray	Fraction SW 1/4 NE 1/4 NE 1/4	Section number 16	Township number T 26	Range number S R 30	Block E	
2. Distance and direction from nearest town or city: miles west, 1 south of Ingalls Street address of well location if in city:	3. Owner of well: Don Redger R.R. or street: RFB City, state, zip code: Ingalls, Kansas 67853						
4. Locate with "X" in section below:  	Sketch map:					6. Bore hole dia. 9 7/8 in. Completion date _____ Well depth 230 ft. 7-12-77	
						7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input checked="" type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
						8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
						9. Casing: Material PVC Height: Above or <input type="checkbox"/> Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 2.8 lbs./ft. Dia. 5 in. to 230 ft. depth Wall Thickness: inches or Dia. in. to ft. depth gauge No. 265	
						10. Screen: Manufacturer's name Jess & Lowell	
						Type PVC Dia. 5" ft. Slot/gauge fine Length 50' Set between 100 ft. and 230 ft. ft. and ft. Gravel pack? Yes Size range of material 1/64-5/32	
						11. Static water level: mo./day/yr. 71 ft. below land surface Date 6/28/77	
						12. Pumping level below land surfaces: ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield g.p.m.	
						13. Water sample submitted: mo./day/yr. Yes <input checked="" type="checkbox"/> No Date	
						14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Unit Inches above grade	
						15. Well grouted? Yes With: Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 4 ft. to 14 ft.	
						16. Nearest source of possible contamination: ft. 300 Direction north Type sewer Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
						17. Pump: Not installed Manufacturer's name Aermotor Model number SD19 HP 1/2 Volts 220 Length of drop pipe 147 ft. capacity 20 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)						18. Elevation:  Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks:
						20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Friesen Windmill 252 Business name <input type="checkbox"/> Address Meade, Kansas 67864 Signed <input type="checkbox"/> Date 8-26-77 Authorized representative	