



USE TYPEWRITER OR BALL
POINT PEN PRESS FIRMLY.
PROTECT RECORD.

JUN 1975

ENVIRONMENTAL
HEALTH

_____ T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

WATER WELL RECORD
KSA 82a-1201-1215

County Location of well:	Township name	Fraction	Section number	Town number	Range number
Gray	Ingalls	SE ¹	17	26	30


Distance and direction from nearest town or city: 6 Miles South and
4 West of Charleston

Street address of well location if in city:

3 Owner of well: Herman Smith
Ingalls, Kansas

Address:

Locate with "X" in section below:



Sketch map:

4 Well depth: 200 ft. Date of completion 6-20-75 Well diameter 26 in.		
5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well		
7 Casing: Material steel Height: above/below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. Diam. Weight lbs./ft. 16 in. to 200 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No in. to ft. depth		
8 Screen: Manufacturer W. A. Brown Type Free Flo Dia. 16 Slot/gauze slot Length 2" Set between 120 ft. and 200 ft. Fittings: Gravel pack <input type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 5/8		
9 Static water level: 50 ft. below land surface Date 6-20-75		
10 Pumping level below land surfaces: Not Test Pumped ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 1200 g.p.m.		
11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date		
12 Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade		
13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite Depth: From 0 ft. to 10 ft.		
14 Nearest source of possible contamination: None Known ft. Direction Type Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
15 Pump: Not installed Manufacturer's name Winthroath Model number 1955 HP 70 Volts Length of drop pipe 180 ft. capacity 1200 m.p. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Dunahm Drilling 223 Business name <i>Dunahm Drilling</i> License No. Address Copeland, Kansas Signed <i>Dunahm Drilling</i> Date 6-20-75 Authorized representative		
16 Remarks: elevation Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley Sand Hills		
(use a second sheet if needed)		