

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County	Fraction	Section number	Township number	Range number		
	Gray	NW 1/4 SE 1/4 NE 1/4	21	26	S	30	
2. Distance and direction from nearest town or city: South of Piercerville Ks. to Plymell Jct., 5 east, 2 south Street address of well location if in city: 1/4 Southwest	Owner of well:	Menno Isaac					
	R.R. or street:	Ingalls, Ks. 67853					
4. Locate with "X" in section below:	Sketch map:	6. Bore hole dia. 26 in. Completion date 8-3-75 Well depth 345 ft.					
		7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary					
5. Type and color of material	From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other				
			9. Casing: Material Steel Height: Above or bottom in. Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 346 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 219 MHC				
			10. Screen: Manufacturer's name Johnson Division Type Galv. Dia. 16"				
			11. Static water level: <input type="checkbox"/> 99 ft. below land surface Date 8-16-75 Set between 290 ft. and 310 ft. Perf: 115-130, 150, 230, 250-290, 310 ft. 345 Gravel pack? <input checked="" type="checkbox"/> Yes Size range of material 1/2" down				
			12. Pumping level below land surfaces: 114 ft. after 2 hrs. pumping 805 g.p.m. 121 ft. after 4 hrs. pumping 1227 g.p.m. Estimated maximum yield 1200 g.p.m.				
			13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date				
			14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade				
			15. Well grouted? <input checked="" type="checkbox"/> Yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.				
			16. Nearest source of possible contamination: N/A ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No				
			17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Goulds - XXX U.S. Model number K-2143 HP 100 Volts Length of drop pipe 160 ft. capacity 1200 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other				
(Use a second sheet if needed)			18. Elevation: 19. Remarks:				
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drilling Co. 208 Business name <input type="checkbox"/> License No. Address Box 493 Garden City, Ks. Signature Authorized representative <input type="checkbox"/> Date 11-21	

WYATT WILSON DRILLING CO. INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 270-3267 • • P.O. Box 493 • • GARDEN CITY, KANSAS 67846

Menno Isaac
Gray County
7-29-75

Location: Pivot NE₁ 21-26-30 East

Test #1

0	2	Top soil
2	11	Brown clay
11	65	Fine sand
65	129	Fine to med. sand & gravel (loose)
129	147	Brown clay
147	185	Fine to med. sand & gravel (loose)
185	191	Fine to med. sand & gravel with 10% clay
191	200	Brown sandy clay
200	229	Fine to med. sand & gravel, 10% clay
229	250	Brown clay
250	262	Fine to med. sand & gravel, 15% clay
262	315	Fine to med. sand & gravel (loose)
315	320	Brown sandy clay
320	345	Fine to med. sand & gravel
345	363	Brown clay
363	365	Shale (hard)

Static Water Level: 100

T.D. 345'