


USE TYPEWRITER OR BALL  
POINT PEN. PRESS FIRMLY.  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:	County: Gray	Fraction: NE 1/4 SW 1/4 NW 1/4	Section number: 21	Township number: 26	Range number: 30
2. Distance and direction from nearest town or city: Ks. to Plymell, 2 south, 3/4 west, Street address of well location if in city: 1/4 south		3. Owner of well: MENNO ISAAC		R.R. or street: Ingalls, Ks. 67853	
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 26 in. Completion date 8-2-75 Well depth 335 ft.	
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
				9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 336 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 219 MTC	
				10. Screen: Manufacturer's name Johnson Division Type Galv. Dia. 16" Slot/gauze <input type="checkbox"/> Length 20' Set between 270 ft. and 290 ft. Perf: 120-200, 270-290, 335 ft. Gravel pack? yes Size range of material 1/2" down	
				11. Static water level: 68 ft. below land surface Date 8-16-75 mo./day/yr.	
				12. Pumping level below land surfaces: 86 ft. after 2 hrs. pumping 805 g.p.m. 96 ft. after 4 hrs. pumping 1337 g.p.m. Estimated maximum yield 1300 g.p.m.	
				13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date	
				14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade	
				15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
				16. Nearest source of possible contamination: N/A ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Goulds - U.S. Model number K-2144 HP 100 Volts <input type="checkbox"/> Length of drop pipe 190 ft. capacity 1300 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
		(Use a second sheet if needed)		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drilling Co. 208 Business name <input type="checkbox"/> Address Box 493 Garden City, Ks. License No. <input type="checkbox"/> Signature <input type="checkbox"/> Date 11-21-75 Authorized representative <input type="checkbox"/>	
18. Elevation:	19. Remarks:				
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					

# WILHELMSON DRILLING CO.

INCORPORATED

Irrigation  
and Domestic  
Water Systems  
Complete Installation  
and Repairing

Phone 376-0762 P.O. Box 493 • GARDEN CITY, KANSAS 67846

Menno Isaac  
Gray County  
7-30-75

Location: Pivot 20 ft. west NW 21-26-30

Test #2

0	2	Top soil
2	39	Brown sandy clay
39	140	Fine to med. sand & gravel
140	152	Brown clay with white rock, hard streaks
152	185	Fine to med. sand & gravel
185	189	Brown sandy clay
189	200	Fine to med. sand & gravel
200	226	Brown clay
226	231	Brown sandy clay
231	290	Fine to med. sand & gravel
290	305	Fine to med. sand & gravel, 30% clay
305	310	Brown clay with white & yellow rock
310	335	Fine to med. sand & gravel
335	353	Brown, Yellow & Gray clay
353	360	Shale (hard)

Static Water Level: 100

T.D. 335'