


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Gray	Fraction NE $\frac{1}{4}$ NE $\frac{1}{4}$ SW $\frac{1}{4}$	Section number 24	Township number T 26 S	Range number R 30 E (W)
2. Distance and direction from nearest town or city: Street address of well location if in city:	6 $\frac{3}{4}$ south, $\frac{1}{4}$ east, 100 yds. north of Charleston, Ks.		3. Owner of well: R.R. or street: City, state, zip code:	Rudy Eichenauer Ingalls, Ks. 67853	
4. Locate with "X" in section below:	Sketch map:			6. Bore hole dia. 26 in. Completion date 6-15-75 Well depth 264 ft.	
			7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
5. Type and color of material	From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material Steel Height: Above <input type="checkbox"/> below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 265 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gauge No. <input type="checkbox"/>		
			10. Screen: Manufacturer's name <input type="checkbox"/> Johnson Division Type Galv. Dia. 16" Slot/gauge <input type="checkbox"/> Length 20' Set between 175 ft. and 185 ft. 240 ft. and 250 ft. Gravel pack? <input checked="" type="checkbox"/> Yes Size range of material $\frac{1}{2}$ " down		
			11. Static water level: 61 mo./day/yr. ft. below land surface Date 6-20-75		
			12. Pumping level below land surfaces: 91 ft. after 2 hrs. pumping 791 g.p.m. 116 ft. after 4 hrs. pumping 1272 g.p.m. Estimated maximum yield 1200 g.p.m.		
			13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>		
			14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade		
			15. Well grouted? <input checked="" type="checkbox"/> yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
			16. Nearest source of possible contamination: N/A ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
			17. Pump: Not installed Manufacturer's name Peerless-FMC Model number 4907 HP 100 Volts <input type="checkbox"/> Length of drop pipe 140 ft. capacity 1200 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drilling Co. 208 Business name <input type="checkbox"/> License No. Address <input type="checkbox"/> Box 493 Garden City, Ks. Signature <input type="checkbox"/> Date 10-13-75 Authorized representative <input type="checkbox"/>		
18. Elevation:	19. Remarks:				
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

Professional MAYER-WILSON DRILLING CO.
INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

RUDY EICHENAUER

Gray County

5-20-75

Location: 150 ft. northwest of No. 4 Sd⁴ 24-26-30

Test # 5

0	2	Top soil	NO.
2	23	Brown clay and fine sand	
23	37	Brown clay	
37	52	Fine to med. sand and gravel, 20% clay (loose)	
52	95	Fine to med. sand and gravel (loose)	
95	110	Brown sandy clay, streaks of white rock	2
110	125	Fine to med. sand and gravel (loose)	2
125	146	Brown clay	4
146	155	Fine to med. sand and gravel (loose)	4
155	161	Fine to med. sand and gravel (small hard streaks)	4
161	185	Fine to med. sand and gravel (loose)	—
185	194	Fine to med. sand and fine gravel, 10% clay (loose)	2
194	221	Brown sandy clay	7
221	230	Fine to med. sand and fine gravel, 15% clay (loose)	1
230	264	Fine to med. sand and fine gravel, 10% clay (loose)	—
264	270	Brown clay	—
270	275	Brown and yellow clay with white rock (hard)	—

T.D. 264'

20' Screen

Static Water Level: 60'