

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County	Fraction	Section number	Township number	Range number
	GRAY	NE 1/4 SW 1/4 NE 1/4	25	T 26 S	R 30 W
2. Distance and direction from nearest town or city: 3/4 north, 1/2 west of Charleston	Street address of well location if in city:	3. Owner of well: R.R. or street: City, state, zip code:	Louis Beery (Carolyn Crotts) Cimarron, KS 67835		
4. Locate with "X" in section below: 	Sketch map:	6. Bore hole dia. 26 in. Completion date 10-16-76 Well depth 230 ft.			
7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
9. Casing: Material steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 231 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <input type="checkbox"/>			10. Screen: Manufacturer's name Johnson Screen Type Galv. Dia. 16" Slot/gauze 200 Length 20' Set between 200 ft. and 220 ft. Perf: 100-200 and 220-230 ft. Gravel pack? yes Size range of material 1/2" down		
11. Static water level: 79 ft. below land surface Date 9-27-76			12. Pumping level below land surfaces: 114 ft. after 3 hrs. pumping 1450 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 1450 g.p.m.		
13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>			14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade		
15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.			16. Nearest source of possible contamination: N/A ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type Field mc Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Goulds US Pump Model number 12JHC HP 100 Volts <input type="checkbox"/> Length of drop pipe 160 ft. capacity 1000 g.p.m.			18. Elevation: 26 Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		
(Use a second sheet if needed)			19. Remarks: Mitter Wilson Drilling 208 Business name Box A Garden city, KS License No. Address 2-26 1/4 1/4 Signed Ben Mitter Date 2-26-76 Authorized representative Ben Mitter		
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.					

The Professionals **MINTER-WILSON DRILLING CO.** INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

CAROLYN CROFTS
LEWIS BARRY Tenant
GRAY COUNTY
9-15-76

Location: NE^{1/4} 25-26-30 offset 300 West of pivot
Static Water Level- 76'

Test #C

0	1	Top soil
1	11	Fine sand
11	17	Brown sandy clay
17	23	Fine sand
23	29	Brown sandy clay
29	37	Fine sand
37	58	Fine to med. sand gravel
58	83	Fine to med. sand and gravel 10% clay
83	89	Fine to med. sand and gravel Loose
89	106	Brown sandy clay
106	126	Fine to med. sand and gravel
126	136	Fine to med. sand trace of cemented sand stone
136	141	Cemented sand stone
141	150	Fine to med. sand and gravel some white rock
150	163	Brown and gray mixed
163	188	Fine sand
188	197	Brown sandy clay
197	229	Fine to med. sand and gravel
229	238	Brown sandy clay mixed with rock pull down
238	243	Yellow clay mixed with rock hard pull down
243	245	Shale

TD 230