


USE TYPEWRITER OR BALL  
POINT PEN-RESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:	County <b>GRAY</b>	Fraction <b>SE 1/4 NW 1/4 SE 1/4</b>	Section number <b>2 5</b>	Township number <b>T 26 S R 30</b>	Range number <b>10</b>
2. Distance and direction from nearest town or city: <b>8 south, 1 east</b> <b>1/2 north, 1/2 west of Charleston</b> Street address of well location if in city:	3. Owner of well: <b>Carolyn Crotts</b> <b>Louis Beery</b> City, state, zip code: <b>Cimarron, KS 67846</b>				
4. Locate with "X" in section below:  	Sketch map:				
6. Bore hole dia. <b>26</b> in. Completion date <b>10-14-76</b> Well depth <b>232</b> ft.					
7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary					
8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other					
9. Casing: Material <b>steel</b> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>12</b> in. RMP <b>16</b> PVC Weight <b>36.87</b> /ft. Dia. <b>16</b> in. to <b>233</b> ft. depth Wall Thickness: inches or Dia. <b>16</b> in. to <b>233</b> ft. depth gage No.					
10. Screen: Manufacturer's name <b>Johnson Screen</b> Type <b>Galv.</b> Dia. <b>16"</b> Slot/gauze <b>20</b> Length <b>20'</b> Set between <b>200</b> ft. and <b>220</b> ft. Perf: <b>100200</b> ft. and <b>220-232</b> ft. Gravel pack? <b>yes</b> Size range of material <b>1/2" down</b>					
11. Static water level: mo./day/yr. <b>17</b> ft. below land surface Date <b>9-27-76</b>					
12. Pumping level below land surfaces: <b>115</b> ft. after <b>3</b> hrs. pumping <b>1500</b> g.p.m. <b>115</b> ft. after <b>3</b> hrs. pumping <b>1500</b> g.p.m. Estimated maximum yield <b>1500</b> g.p.m.					
13. Water sample submitted: mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date					
14. Well head completion: <input type="checkbox"/> Pitless adapter <b>12</b> inches above grade					
15. Well grouted? <b>yes</b> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <b>0</b> ft. to <b>10</b> ft.					
16. Nearest source of possible contamination: <b>N/A</b> ft. <b>Field</b> Direction <b>NE</b> Type <b>Field</b> Well disinfected upon completion? <b>yes</b> <input checked="" type="checkbox"/> No					
17. Pump: Not installed Manufacturer's name <b>Goulds US Pump</b> Model number <b>12.IHC</b> HP <b>100</b> Volts <b>115</b> Length of drop pipe <b>160</b> ft. capacity <b>1000</b> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other					
18. Elevation:  Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					
19. Remarks:  (Use a second sheet if needed)					
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Minter Wilson Drilling 208</b> Business name <b>Minter Wilson Drilling 208</b> License No. Address <b>P.O. Box A Garden City, KS</b> Date <b>9-27-76</b> Signature <b>Minter Wilson</b> Authorized representative					

*the Professionals* **MINTER-WILSON DRILLING CO.** INCORPORATED

Irrigation  
and Domestic  
Water Systems  
Complete Installation  
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

CAROLYN CROFTS  
LEWIS BARRY Tenant  
GRAY COUNTY  
9-11-76

Location: SEC 25-26-30 offset 300 south of pivot  
Static Water Level- 76

Test #A

0	1	Top soil
1	6	Fine sand
6	16	Brown sandy clay
16	55	Fine sand loose
55	59	Fine to med. sand
59	63	Brown sandy clay
63	80	Fine to med. sand and gravel Loose
80	89	Fine to med. sand and gravel some coarse gravel Loose
89	103	Brown ish sandy clay
103	123	Fine to med. sand
123	136	Light brown sandy clay
136	143	Fine to med. sand
143	151	Cemented sandstone mixed white yellow rock hard
151	169	Fine to med. sand and gravel mixed white yel- low rock loose
169	178	Brown sandy clay
178	191	Fine to med. sand and gravel Loose
191	202	Brown sandy clay
202	212	Fine to med. sand and gravel
212	232	Fine to med. sand and gravel mixed white yellow rock Loose
232	250	Brown yellow mixed
250	255	Shale