


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Gray	Fraction NW 1/4 SE 1/4 NE 1/4	Section number 35	Township number T 26	Range number S R 30 X/W
2. Distance and direction from nearest town or city:	8 miles so. of Charleston, Ks.		3. Owner of well: Henry Schmidt		
Street address of well location if in city:		R.R. or street: Montezuma, Ks. 67867			
4. Locate with "X" in section below:	Sketch map: 		6. Bore hole dia. 9 1/8 in. Completion date _____ Well depth 218 ft. 6-13-79		
			7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material PVC Height: Above or <input checked="" type="checkbox"/> Below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP _____ PVC <input checked="" type="checkbox"/> Weight 2.8 lbs./ft. Dia. 5 in. to 218 ft. Wall Thickness, inches or Dia. _____ in. to _____ ft. depth gage No. 375		
5. Type and color of material	From 0	To 60	10. Screen: Manufacturer's name Pumpco Type PVC Dia. 5 Slot/gauze fine Length 60 Set between 158 ft. and 218 ft. ft. and _____ ft. Gravel pack? Yes Size range of material 1/16-5/32		
Fine Sand			11. Static water level: mo./day/yr. 100 ft. below land surface Date 5-23-79		
Med. sand	60	78	12. Pumping level below land surfaces: ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 50++ g.p.m.		
Med. to Lar. Sand	78	120	13. Water sample submitted: mo./day/yr. Yes <input checked="" type="checkbox"/> No Date		
Med. to Lar. Sand Gravel	120	152	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter Inches above grade		
Med. to Lar. Sand with yellow clay streaks gravel	152	218	15. Well grouted? Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 4 ft. to 14 ft.		
Clay tough & sticky	218	223	16. Nearest source of possible contamination: ft. 40 Direction E Type old well Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
WD-218'			17. Pump: Not installed Manufacturer's name Aermotor Model number SD19 HP 1/2 Volts 220 Length of drop pipe 168 ft. capacity 20 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)			18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		
19. Remarks:			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Friesen Windmill 252 Business name _____ License No. _____ Address Meade, Kansas 67864 Signed _____ Authorized representative _____ Date 11/26/79		