

13,146

KSA 82a-1212

*The
Professionals*

MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box A • GARDEN CITY, KANSAS 67846

Ross Ardery
Finney County
4-23-07

Location: SW $\frac{1}{4}$ 26-26-31 - Pierceville Black Top & Lear Road -
 $\frac{1}{4}$ mile north & 1/8th of a mile east
- west of well

Static Water Level -

Test #2

0' to 1' - Top soil
1' to 10' - Brown sandy clay
10' to 37' - Brown clay
37' to 61' - Brown sandy clay
61' to 104' - Fine to medium sand & gravel with some coarse
104' to 112' - Brown clay
112' to 148' - Fine to medium sand & gravel - 10% clay
148' to 153' - Fine to medium sand & gravel cemented
153' to 171' - Brown sandy clay
171' to 186' - Fine to medium sand & gravel - 10% clay
186' to 200' - Brown sandy clay
200' to 225' - Fine to medium sand & gravel
225' to 242' - Fine to medium sand & gravel with clay strips
242' to 268' - Brown sandy clay
268' to 272' - Fine to medium sand
272' to 285' - Brown sandy clay
285' to 290' - Fine to medium sand
290' to 327' - Brown sandy clay
327' to 331' - Fine to medium sand & fine gravel
331' to 357' - Brown sandy clay
357' to 361' - Fine to medium sand
361' to 371' - Brown clay
371' to 379' - Brown clay with brown rock mixed
379' to 421' - Brown yellow clay - hard
421' to 425' - Shale - hard pull down