

WATER WELL RECORD

Form WWC-5

Division of Water Resources App. No.

12,398

1 LOCATION OF WATER WELL: County: FINNEY	Fraction LO 1/4 T4 1/4 SW 1/4 SW 1/4	Section Number 18	Township No. T 26 S	Range Number R 31 <input type="checkbox"/> E <input checked="" type="checkbox"/> W
Street/Rural Address of Well Location; if unknown, distance & direction from nearest town or intersection: If at owner's address, check here <input type="checkbox"/> GARDEN CITY-12 M S ON HWY 83 TO TV RD, 7 M E, 175 FT. NORTH & 4,619 FT. WEST		Global Positioning System (GPS) information: Latitude: (in decimal degrees) Longitude: (in decimal degrees) Elevation: Datum: <input type="checkbox"/> WGS 84, <input type="checkbox"/> NAD 83, <input type="checkbox"/> NAD 27 Collection Method: <input type="checkbox"/> GPS unit (Make/Model:) <input type="checkbox"/> Digital Map/Photo, <input type="checkbox"/> Topographic Map, <input type="checkbox"/> Land Survey Est. Accuracy: <input type="checkbox"/> <3 m, <input type="checkbox"/> 3-5 m, <input type="checkbox"/> 5-15 m, <input type="checkbox"/> >15 m		
2 WATER WELL OWNER: TERRY K. & CONNIE GIGOT RR#, Street Address, Box #: 1115 HARDING ST. City, State, ZIP Code : GARDEN CITY, KANSAS 67846				

3 LOCATE WELL WITH AN "X" IN SECTION BOX: N W E S -----1 mile-----	4 DEPTH OF COMPLETED WELL 430 ft. Depth(s) Groundwater Encountered (1)..... ft. (2)..... ft. (3)..... ft. WELL'S STATIC WATER LEVEL 210ft. below land surface measured on mo/day/yr. 6-2-14 Pump test data: Well water was.....ft. after..... hours pumping..... gpm EST. YIELD.....gpm. Well water was.....ft. after..... hours pumping..... gpm Bore Hole Diameter .30in. to 430ft., andin. toft. WELL WATER TO BE USED AS: <input type="checkbox"/> Public water supply <input type="checkbox"/> Geothermal <input type="checkbox"/> Injection well <input type="checkbox"/> Domestic <input type="checkbox"/> Feedlot <input type="checkbox"/> Oil field water supply <input type="checkbox"/> Dewatering <input type="checkbox"/> Other (Specify below) <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Industrial <input type="checkbox"/> Domestic-lawn & garden <input type="checkbox"/> Monitoring well Was a chemical/bacteriological sample submitted to Department? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If yes, mo/day/yr sample was submitted..... Water well disinfected? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
--	--

5 TYPE OF CASING USED: Steel PVC Other

CASING JOINTS: Glued Clamped Welded Threaded
Casing diameter **.16**..... in. to **BELOW**..... ft., Diameter in. to ft., Diameter in. to ft.
Casing height above land surface..... **12**..... in., Weight **42.05**.....lbs./ft., Wall thickness or gauge No. **250**.....

TYPE OF SCREEN OR PERFORATION MATERIAL:
 Steel Stainless Steel PVC Other (Specify)
 Brass Galvanized Steel None used (open hole)

SCREEN OR PERFORATION OPENINGS ARE:
 Continuous slot Mill slot Gauze wrapped Torch cut Drilled holes None (open hole)
 Louvered shutter Key punched Wire wrapped Saw cut Other (specify)

SCREEN-PERFORATED INTERVALS: From **260**..... ft. to **340**..... ft., From **380**..... ft. to **430**..... ft.
From..... ft. to ft., From..... ft. to ft.

GRAVEL PACK INTERVALS: From **20**..... ft. to **185**..... ft., From **245**..... ft. to **430**..... ft.
From..... ft. to ft., From..... ft. to ft.

6 GROUT MATERIAL: Neat cement Cement grout Bentonite Other

Grout intervals: From **0**..... ft. to **20**..... ft., From **185**..... ft. to **245**..... ft., From..... ft. toft.

What is the nearest source of possible contamination:
 Septic tank Lateral lines Pit privy Livestock pens Insecticide storage Other (specify below)
 Sewer lines Cesspool Sewage lagoon Fuel storage Abandoned water well
 Watertight sewer lines Seepage pit Feedyard Fertilizer storage Oil well/gas well **N/A**.....
Direction from well Distance from well

FROM	TO	LITHOLOGIC LOG	FROM	TO	LITHO. LOG (cont.) or PLUGGING INTERVALS
0'	260'	16" PLAIN CASING			
260'	300'	16" JOHNSON AGRI SCREEN			
300'	340'	16" MILL SLOT PERF.			SEE ATTACHED LOG
340'	380'	16" PLAIN CASING			
380'	420'	16" JOHNSON AGRI SCREEN			
420'	430'	16" MILL SLOT PERF.			

7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was constructed, reconstructed, or plugged under my jurisdiction and was completed on (mo/day/year) ...**6-2-14**..... and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. ...**208**..... This Water Well Record was completed on (mo/day/year) ...**6-5-14**..... under the business name of **MINTER-WILSON DRILLING CO., INC.**..... by (signature) *Nora Keller*.....

INSTRUCTIONS: Use typewriter or ball point pen. **PLEASE PRESS FIRMLY** and **PRINT** clearly. Please fill in blanks and check the correct answers. Send one copy to Kansas Department of Health and Environment, Bureau of Water, Geology Section, 1000 SW Jackson St., Suite 420, Topeka, Kansas 66612-1367. Telephone 785-296-5524. Send one copy to WATER WELL OWNER and retain one for your records. Include fee of \$5.00 for each constructed well. Visit us at <http://www.kdheks.gov/waterwell/index.html>

*The
Professionals*

MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 620-276-8269 • P.O. Box A • GARDEN CITY, KANSAS 67846

NAME TERRY GIGOT
COUNTY FINNEY
DATE 4-10-14

LOCATION: SW 1/4 18-26-31 - GARDEN CITY - SOUTH TO PLYMELL ROAD - 7 MILES EAST,
2 MILES SOUTH, 1 MILE WEST & 1/2 MILE NORTH
- SOUTHWEST CORNER OF CIRCLE

STATIC WATER LEVEL -

TEST # 2

0' TO 2' - TOP SOIL
2' TO 63' - BROWN SANDY CLAY
63' TO 105' - FINE TO MEDIUM SAND & GRAVEL - SOME COARSE
105' TO 129' - BROWN CLAY
129' TO 144' - BROWN CLAY WITH STREAKS OF GRAVEL
144' TO 185' - FINE TO MEDIUM SAND & FINE GRAVEL - 10% CLAY
185' TO 225' - FINE TO MEDIUM SAND & GRAVEL
225' TO 245' - BROWN CLAY WITH GRAVEL STREAKS
245' TO 254' - FINE TO MEDIUM SAND & GRAVEL
254' TO 260' - BROWN CLAY
260' TO 287' - FINE TO MEDIUM SAND & GRAVEL - 10% CLAY
287' TO 290' - BROWN CLAY
290' TO 310' - BROWN SANDY CLAY
310' TO 380' - BROWN CLAY
380' TO 395' - FINE TO MEDIUM SAND & GRAVEL
395' TO 406' - BROWN CLAY
406' TO 418' - FINE TO MEDIUM SAND & GRAVEL
418' TO 425' - BROWN YELLOW CLAY
425' TO 434' - BROWN YELLOW CLAY - TRACES OF SHALE - HARD
434' TO 440' - SHALE - HARD