

15801 D2

Check: ☒ White Copy, ☐ Blue Copy, ☐ Pink Copy

*The
Professionals*

MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box A • GARDEN CITY, KANSAS 67846

JLM Farms
Finney County
1/26/05

Location: NE $\frac{1}{4}$ 33-26-32 - South on Hwy. 83 to Lear Road, 3 miles east,
 $\frac{1}{4}$ mile south & $\frac{1}{4}$ mile west
 - 300 ft. west of well

Static Water Level - 210 ft.

Test #2

0' to 1' - Top soil
1' to 18' - Brown clay
18' to 42' - Brown sandy clay
42' to 120' - Fine to medium sand & gravel - some coarse
120' to 154' - Brown clay
154' to 163' - Fine to medium sand & gravel
163' to 174' - Brown clay
174' to 218' - Fine to medium sand & gravel - 10% clay
218' to 238' - Brown sandy clay
238' to 248' - Brown clay - small gravel streaks
248' to 331' - Fine to medium sand & gravel
331' to 349' - Brown sandy clay
349' to 361' - Fine to medium sand & gravel
361' to 445' - Brown sandy clay
445' to 448' - Fine to medium sand & fine gravel
448' to 460' - Brown clay
460' to 475' - Fine to medium sand & gravel
475' to 479' - Fine to medium sand & gravel - clay strip
479' to 488' - Fine to medium sand & gravel
488' to 506' - Brown clay
506' to 511' - Brown clay with 30% brown rock
511' to 521' - Brown yellow clay
521' to 530' - Red bed