

11,134

Check: ☒ White Copy, ☐ Blue Copy, ☐ Pink Copy

*The
Professionals*

MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269

P.O. Box A

GARDEN CITY, KANSAS 67846

Al Ohmes
Finney County
3/3/04

Location: NW $\frac{1}{4}$ 23-26-32 - South of Garden City on Hwy. 83 to T.V. Road,
4 $\frac{1}{2}$ miles east, 57 ft. south to well
- Offset well - 408 ft. west

Static Water Level - Approx. 200 ft.

Test #1

0' to 1' - Top soil
1' to 6' - Brown clay
6' to 12' - Brown sandy clay
12' to 17' - Fine sand
17' to 34' - Brown sandy clay
34' to 44' - Fine sand - loose
44' to 68' - Brown clay
68' to 90' - Fine to medium sand & gravel
90' to 97' - Brown clay
97' to 129' - Fine to medium sand & gravel - clay streak
129' to 135' - Brown sandy clay - small gravel streak
135' to 190' - Gray clay
190' to 193' - Fine sand
193' to 202' - Gray clay
202' to 260' - Blue clay
260' to 268' - Brown clay
268' to 273' - Brown clay - gravel streak
273' to 293' - Fine to medium sand & gravel
293' to 322' - Fine to medium sand & gravel - 10% clay
322' to 337' - Brown clay
337' to 344' - Fine to medium sand & gravel
344' to 365' - Brown clay
365' to 374' - Brown sandy clay - small gravel strip
374' to 380' - Fine to medium sand & gravel
380' to 414' - Brown clay white rock mixed
414' to 494' - Brown clay
494' to 503' - Fine to medium sand brown rock mixed - clay strip
503' to 513' - Yellow clay - hard pull down 200
513' to 515' - Shale - hard pull down 200