

WATER WELL RECORD

Form WWC-5

Division of Water Resources App. No.

1 LOCATION OF WATER WELL: County: Finney	Fraction ¼ NW ¼ NW ¼ NW ¼	Section Number 20	Township No. T 26 S	Range Number R 32 <input type="checkbox"/> E <input checked="" type="checkbox"/> W
Street/Rural Address of Well Location; if unknown, distance & direction from nearest town or intersection: If at owner's address, check here <input type="checkbox"/> 83 Hwy & TV Rd. 1 Mile East to Co. Rd 14, 275' East and 305' South to Well		Global Positioning System (GPS) information: Latitude: (in decimal degrees) Longitude: (in decimal degrees) Elevation: Datum: <input type="checkbox"/> WGS 84, <input type="checkbox"/> NAD 83, <input type="checkbox"/> NAD 27 Collection Method: <input type="checkbox"/> GPS unit (Make/Model:) <input type="checkbox"/> Digital Map/Photo, <input type="checkbox"/> Topographic Map, <input type="checkbox"/> Land Survey Est. Accuracy: <input type="checkbox"/> <3 m, <input type="checkbox"/> 3-5 m, <input type="checkbox"/> 5-15 m, <input type="checkbox"/> >15 m		
2 WATER WELL OWNER: Heiman Family Farms RR#, Street Address, Box #: 9460 S. Rd. 15 City, State, ZIP Code : Garden City. KS 67846				

3 LOCATE WELL WITH AN "X" IN SECTION BOX: 	4 DEPTH OF COMPLETED WELL 510 ft. Depth(s) Groundwater Encountered (1)..... ft. (2)..... ft. (3)..... ft. WELL'S STATIC WATER LEVEL 310ft. below land surface measured on mo/day/yr..... Pump test data: Well water was 330ft. after 4 hours pumping 34 gpm EST. YIELD 75gpm. Well water wasft. after hours pumping gpm Bore Hole Diameter 10in. to 510ft., andin. toft. WELL WATER TO BE USED AS: <input type="checkbox"/> Public water supply <input type="checkbox"/> Geothermal <input type="checkbox"/> Injection well <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Feedlot <input type="checkbox"/> Oil field water supply <input type="checkbox"/> Dewatering <input type="checkbox"/> Other (Specify below) <input type="checkbox"/> Irrigation <input type="checkbox"/> Industrial <input type="checkbox"/> Domestic-lawn & garden <input type="checkbox"/> Monitoring well Was a chemical/bacteriological sample submitted to Department? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If yes, mo/day/yr sample was submitted..... Water well disinfected? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
--	--

5 TYPE OF CASING USED: Steel PVC Other Splined.....
 CASING JOINTS: Glued Clamped Welded Threaded
 Casing diameter 5 in. to 390 ft., Diameter in. to ft., Diameter in. to ft.
 Casing height above land surface 16 in., Weight 250 lbs./ft., Wall thickness or gauge No. SDR17.....
TYPE OF SCREEN OR PERFORATION MATERIAL:
 Steel Stainless Steel PVC Other (Specify)
 Brass Galvanized Steel None used (open hole)
SCREEN OR PERFORATION OPENINGS ARE:
 Continuous slot Mill slot Gauze wrapped Torch cut Drilled holes None (open hole)
 Louvered shutter Key punched Wire wrapped Saw cut Other (specify)
SCREEN-PERFORATED INTERVALS: From 390 ft. to 510 ft., From ft. to ft.
GRAVEL PACK INTERVALS: From 25 ft. to 345 ft., From 355 ft. to 510 ft.
 From ft. to ft., From ft. to ft.

6 GROUT MATERIAL: Neat cement Cement grout Bentonite Other
 Grout Intervals: From 5 ft. to 25 ft., From 345 ft. to 355 ft., From ft. to ft.
 What is the nearest source of possible contamination:
 Septic tank Lateral lines Pit privy Livestock pens Insecticide storage Other (specify below)
 Sewer lines Cesspool Sewage lagoon Fuel storage Abandoned water well
 Watertight sewer lines Seepage pit Feedyard Fertilizer storage Oil well/gas well
 Direction from well North West Distance from well 135'.....

FROM	TO	LITHOLOGIC LOG	FROM	TO	LITHO. LOG (cont.) or PLUGGING INTERVALS
0	2	Top Soil	266	330	Medium To Coarse Sand Small Gravel
2	26	Brown Clay	330	363	Brown Clay
26	44	Fine To Medium Sand	363	382	Medium To Coarse Sand Small Gravel
44	80	Brown Clay Gypsum Streaks	382	409	Brown Clay Few Small Sand Streaks
80	114	Coarse Sand Small To Medium Gravel	409	415	Medium To Coarse Sand Small Gravel
114	124	Brown Clay With Medium Gravel Str.	415	452	Brown Clay With Medium Sand Streaks
124	152	Medium Sand Small To Medium Gravel	452	484	Fine-Med. Sand Few Brown Clay Str.
152	164	Brown Clay Gypsum Cemented Sand	484	494	Brown Clay
164	262	Medium To Coarse Sand Small Gravel	494	504	Brown Clay With Fine Sand Streaks
262	266	Brown Clay	504	510	Fine Sand

7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was constructed, reconstructed, or plugged under my jurisdiction and was completed on (mo/day/year) 11-14-19..... and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 532..... This Water Well Record was completed on (mo/day/year) 12-18-19..... under the business name of Midwest Well & Pump Inc...... by (signature) [Signature].....

INSTRUCTIONS: Use typewriter or ball point pen. *PLEASE PRESS FIRMLY* and *PRINT* clearly. Please fill in blanks and check the correct answers. Send three copies (white, blue, pink) to Kansas Department of Health and Environment, Bureau of Water, Geology Section, 1000 SW Jackson St., Suite 420, Topeka, Kansas 66612-1367. Telephone 785-296-5522. Send one copy to WATER WELL OWNER and retain one for your records. Include fee of \$5.00 for each constructed well. Visit us at <http://www.kdheks.gov/waterwell/index.html>.