

[illegible]



# MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation  
and Domestic  
Water Systems  
Complete Installation  
and Repairing

Phone 276-8269 • P.O. Box A • GARDEN CITY, KANSAS 67846

Stone Acres Inc.  
Finney County  
10/11/04

Location: NW $\frac{1}{4}$  20-26-33 -From Ivanhoe Road- 3 miles south, 1 mile east,  $\frac{1}{2}$  mile south  
east side of road

Static Water Level - 198 ft.

## Test # 1

0' to 2' - Top Soil  
2' to 15' - Brown Sandy Clay, loose  
15' to 22' - Brown Clay  
22' to 38' - Brown Sandy Clay  
38' to 45' - Fine to medium sand and gravel  
45' to 148' - Medium coarse gravel  
148' to 154' - Brown Clay  
154' to 165' - Fine to medium sand and gravel, hard cemented strip  
165' to 207' - Fine to medium sand and gravel  
207' to 217' - Brown Clay  
217' to 235' - Blue clay  
235' to 241' - Brown sandy clay small gravel streak  
241' to 262' - Fine to medium sand and gravel 10% clay  
262' to 277' - Fine to medium sand and gravel tight  
277' to 280' - Brown white clay  
280' to 285' - Fine to medium sand and gravel  
285' to 306' - Brown sandy clay  
306' to 310' - Fine to medium sand and gravel  
310' to 319' - Brown clay  
319' to 326' - Fine to medium sand and gravel  
326' to 341' - Brown sandy clay  
341' to 374' - Brown clay  
374' to 383' - Brown clay white rock mixed  
383' to 433' - Brown clay  
433' to 455' - Fine to medium sand and gravel brown rock mixed  
455' to 470' - Brown yellow clay