

[illegible]

*The
Professionals*

MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box A • GARDEN CITY, KANSAS 67846

Billy Stone
Finney County
12/9/04

Location: SE $\frac{1}{4}$ 7-26-33 - From Ivanhoe - 2 $\frac{1}{2}$ Miles South, 6/10 Mile East
80 Ft. North

Static Water Level - 190 Ft.

Test # 1

0'	to	1'	- Top Soil
1'	to	23'	- Brown Clay
23'	to	27'	- Fine to medium sand
27'	to	76'	- Fine to medium sand and gravel
76'	to	82'	- Brown Clay
82'	to	128'	- Fine to medium sand and gravel
128'	to	142'	- Cemented sand, Hard
142'	to	187'	- Brown Clay, small gravel
187'	to	235'	- Fine to medium sand
235'	to	254'	- Brown Clay
254'	to	273'	- Fine to medium sand and gravel, Clay streak
273'	to	297'	- Brown Clay
297'	to	314'	- Brown Clay, Small strips of gravel
314'	to	322'	- Fine to medium sand and gravel
322'	to	357'	- Brown Clay
357'	to	364'	- Fine to medium sand, Tight
364'	to	451'	- Brown Clay
451'	to	464'	- Brown Clay sand stone, small brown rock, Tight
464'	to	476'	- Yellow Clay, sand stone small, Brown rock Hard