

32,473

KSA 82a-1212

Check: ☒ White Copy, ☐ Blue Copy, ☐ Pink Copy

*The
Professionals*

MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269

P.O. Box A

GARDEN CITY, KANSAS 67846

Greg Stone
Finney County
12/8/03

Location: SE $\frac{1}{4}$ 14-26-33 - South of Garden City to Ch. 11 - 1 $\frac{1}{4}$ miles west
- north side 1,315 ft. north & 90 ft. east of well

Static Water Level - 225 ft.

Test #1

0' to 1' - Top soil
1' to 8' - Brown sandy clay
8' to 28' - Brown clay
28' to 30' - Fine to medium sand
30' to 35' - Brown clay
35' to 75' - Fine to medium sand & gravel
75' to 80' - Brown clay
80' to 90' - Fine to medium sand & gravel
90' to 131' - Fine to medium sand & gravel - 10% clay
131' to 145' - Brown clay
145' to 165' - Brown sandy clay
165' to 171' - Brown clay with white rock - hard
171' to 176' - Blue clay
176' to 191' - Brown clay with gravel streaks
191' to 229' - Fine to medium sand & gravel
229' to 261' - Brown & blue clay
261' to 281' - Brown clay with small gravel streaks
281' to 313' - Fine to medium sand & gravel - 10% clay
313' to 327' - Brown clay
327' to 330' - Fine to medium sand & gravel
330' to 353' - Brown clay
353' to 364' - Fine to medium sand & gravel
364' to 381' - Brown clay
381' to 400' - Brown sandy clay
400' to 414' - Fine to medium sand
414' to 460' - Brown sandy clay
460' to 468' - Fine to medium sand & fine gravel
468' to 503' - Brown clay
503' to 510' - Brown rock brown clay 15% - loose
510' to 520' - Brown yellow clay
520' to 526' - Yellow clay
526' to 530' - Shale - hard