

## WATER WELL RECORD

## Form WWC-5

Division of Water Resources App. No.

28,622

<b>1 LOCATION OF WATER WELL:</b> County: FINNEY		Fraction ¼ SW ¼ SW ¼ SE ¼	Section Number 5	Township No. T 26 S	Range Number R 33 <input type="checkbox"/> E <input checked="" type="checkbox"/> W				
Street/Rural Address of Well Location; if unknown, distance & direction from nearest town or intersection: If at owner's address, check here <input type="checkbox"/> 10 MILES SOUTH OF GARDEN CITY TO PLYMELL RD, 4 MILES WEST, 280 FT. NORTH & 2,145 FT. WEST			<b>Global Positioning System (GPS) information:</b> Latitude: ...37.81014... (in decimal degrees) Longitude: ...-100.95068... (in decimal degrees) Elevation: ..... Datum: <input type="checkbox"/> WGS 84, <input type="checkbox"/> NAD 83, <input checked="" type="checkbox"/> NAD 27 Collection Method: <input checked="" type="checkbox"/> GPS unit (Make/Model: GARMIN 62ST .....) <input type="checkbox"/> Digital Map/Photo, <input type="checkbox"/> Topographic Map, <input type="checkbox"/> Land Survey Est. Accuracy: <input type="checkbox"/> <3 m, <input type="checkbox"/> 3-5 m, <input type="checkbox"/> 5-15 m, <input type="checkbox"/> >15 m						
<b>2 WATER WELL OWNER:</b> STONE ACRES, INC. RR#, Street Address, Box #: 12500 S. STONE ROAD City, State, ZIP Code : GARDEN CITY, KS 67846									
<b>3 LOCATE WELL WITH AN "X" IN SECTION BOX:</b> N <div style="display: flex; align-items: center; justify-content: center;"> <div style="margin-right: 10px;">W</div> <table border="1" style="border-collapse: collapse; text-align: center;"> <tr> <td style="padding: 5px;">--NW--</td> <td style="padding: 5px;">--NE--</td> </tr> <tr> <td style="padding: 5px;">--SW--</td> <td style="padding: 5px;">--SE--</td> </tr> </table> <div style="margin-left: 10px;">E</div> </div> <div style="text-align: center; margin-top: 5px;">S</div> <div style="text-align: center; margin-top: 5px;">-----1 mile-----</div>		--NW--	--NE--	--SW--	--SE--	<b>4 DEPTH OF COMPLETED WELL</b> ..... 470 ..... ft. Depth(s) Groundwater Encountered (1)..... ft. (2)..... ft. (3)..... ft. WELL'S STATIC WATER LEVEL..... 233 ..... ft. below land surface measured on mo/day/yr. 2-12-13..... Pump test data: Well water was.....ft. after..... hours pumping..... gpm EST. YIELD.....gpm. Well water was.....ft. after..... hours pumping..... gpm Bore Hole Diameter .30.....in. to .....470.....ft., and .....in. to .....ft. WELL WATER TO BE USED AS: <input type="checkbox"/> Public water supply <input type="checkbox"/> Geothermal <input type="checkbox"/> Injection well <input type="checkbox"/> Domestic <input type="checkbox"/> Feedlot <input type="checkbox"/> Oil field water supply <input type="checkbox"/> Dewatering <input type="checkbox"/> Other (Specify below) <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Industrial <input type="checkbox"/> Domestic-lawn & garden <input type="checkbox"/> Monitoring well ..... Was a chemical/bacteriological sample submitted to Department? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If yes, mo/day/yr sample was submitted..... Water well disinfected? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
--NW--	--NE--								
--SW--	--SE--								
<b>5 TYPE OF CASING USED:</b> <input checked="" type="checkbox"/> Steel <input type="checkbox"/> PVC <input type="checkbox"/> Other ..... CASING JOINTS: <input type="checkbox"/> Glued <input type="checkbox"/> Clamped <input checked="" type="checkbox"/> Welded <input type="checkbox"/> Threaded Casing diameter ...16..... in. to BELOW ft., Diameter ..... in. to ..... ft., Diameter ..... in. to ..... ft. Casing height above land surface.....12..... in., Weight 42.05.....lbs./ft., Wall thickness or gauge No. ...250..... TYPE OF SCREEN OR PERFORATION MATERIAL: <input checked="" type="checkbox"/> Steel <input type="checkbox"/> Stainless Steel <input type="checkbox"/> PVC <input type="checkbox"/> Other (Specify) ..... <input type="checkbox"/> Brass <input type="checkbox"/> Galvanized Steel <input type="checkbox"/> None used (open hole) SCREEN OR PERFORATION OPENINGS ARE: <input type="checkbox"/> Continuous slot <input checked="" type="checkbox"/> Mill slot <input type="checkbox"/> Gauze wrapped <input type="checkbox"/> Torch cut <input type="checkbox"/> Drilled holes <input type="checkbox"/> None (open hole) <input type="checkbox"/> Louvered shutter <input type="checkbox"/> Key punched <input checked="" type="checkbox"/> Wire wrapped <input type="checkbox"/> Saw cut <input type="checkbox"/> Other (specify) ..... SCREEN-PERFORATED INTERVALS: From..... BELOW ..... ft. to ..... ft., From ..... ft. to ..... ft. From..... ft. to ..... ft., From ..... ft. to ..... ft. GRAVEL PACK INTERVALS: From..... 20 ..... ft. to ..... 210 ..... ft., From ..... 270 ..... ft. to ..... 470 ..... ft. From..... ft. to ..... ft., From ..... ft. to ..... ft.									
<b>6 GROUT MATERIAL:</b> <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Cement grout <input type="checkbox"/> Bentonite <input type="checkbox"/> Other ..... Grout Intervals: From ..... 0 ..... ft. to ..... 20 ..... ft., From ..... 210 ..... ft. to ..... 270 ..... ft., From ..... ft. to ..... ft. What is the nearest source of possible contamination: <input type="checkbox"/> Septic tank <input type="checkbox"/> Lateral lines <input type="checkbox"/> Pit privy <input type="checkbox"/> Livestock pens <input type="checkbox"/> Insecticide storage <input type="checkbox"/> Other (specify below) <input type="checkbox"/> Sewer lines <input type="checkbox"/> Cesspool <input type="checkbox"/> Sewage lagoon <input type="checkbox"/> Fuel storage <input type="checkbox"/> Abandoned water well <input type="checkbox"/> Watertight sewer lines <input type="checkbox"/> Seepage pit <input type="checkbox"/> Feedyard <input type="checkbox"/> Fertilizer storage <input type="checkbox"/> Oil well/gas well ..... N/A Direction from well ..... Distance from well .....									
FROM	TO	LITHOLOGIC LOG	FROM	TO	LITHO. LOG (cont.) or PLUGGING INTERVALS				
0	290	PLAIN CASING							
290	310	AGRI SCREEN							
310	330	MILL SLOT PERF.			SEE ATTACHED LOG				
330	370	AGRI SCREEN							
370	410	MILL SLOT PERF.							
410	440	PLAIN CASING							
440	460	AGRI SCREEN							
460	470	MILL SLOT PERF.							
<b>7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION:</b> This water well was <input checked="" type="checkbox"/> constructed, <input type="checkbox"/> reconstructed, or <input type="checkbox"/> plugged under my jurisdiction and was completed on (mo/day/year) 2-12-13..... and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 208..... This Water Well Record was completed on (mo/day/year) 2-13-13..... under the business name of MINTER-WILSON DRILLING CO., INC..... by (signature) <i>Tara Keller</i> ..... <b>INSTRUCTIONS:</b> Use typewriter or ball point pen. PLEASE PRESS FIRMLY and PRINT clearly. Please fill in blanks and check the correct answers. Send three copies (white, blue, pink) to Kansas Department of Health and Environment, Bureau of Water, Geology Section, 1000 SW Jackson St., Suite 420, Topeka, Kansas 66612-1367. Telephone 785-296-5524. Send one copy to WATER WELL OWNER and retain one for your records. Include fee of \$5.00 for each constructed well. Visit us at <a href="http://www.kdheks.gov/waterwell/index.html">http://www.kdheks.gov/waterwell/index.html</a> .									

*The  
Professionals*

# MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation  
and Domestic  
Water Systems  
Complete Installation  
and Repairing

Phone 620-276-8269 • P.O. Box A • GARDEN CITY, KANSAS 67846

NAME GREG STONE  
COUNTY FINNEY  
DATE 11-23-12

LOCATION: SE 1/4 5-26-33 - FROM WEST END OF PLYMELL BLACK TOP -  
1/4 MILE WEST & 1/4 MILE NORTH  
- SOUTHWEST EDGE OF CIRCLE

STATIC WATER LEVEL - 260 FT.

## TEST # 4

0' TO 1' - TOP SOIL  
1' TO 15' - BROWN CLAY  
15' TO 43' - BROWN SANDY CLAY  
43' TO 61' - FINE TO MEDIUM SAND & GRAVEL  
61' TO 85' - BROWN CLAY  
85' TO 166' - FINE TO MEDIUM SAND & GRAVEL  
166' TO 188' - BROWN CLAY WITH SMALL GRAVEL STREAKS  
188' TO 199' - BROWN CLAY  
199' TO 228' - BROWN & BLUE CLAY  
228' TO 248' - BROWN CLAY  
248' TO 264' - FINE TO MEDIUM SAND & GRAVEL - 10% CLAY  
264' TO 290' - FINE TO MEDIUM SAND & GRAVEL - CLAY STREAKS  
290' TO 307' - FINE TO MEDIUM SAND & GRAVEL  
307' TO 339' - BROWN CLAY  
339' TO 363' - FINE TO MEDIUM SAND & GRAVEL - 10% CLAY  
363' TO 400' - BROWN CLAY WITH WHITE ROCK MIXED  
400' TO 440' - BROWN CLAY  
440' TO 457' - BROWN ROCK - 20% CLAY - LOOSE  
457' TO 464' - BROWN YELLOW CLAY  
464' TO 470' - SHALE - HARD PULL DOWN