


1 LOCATION OF WATER WELL: County: Finney		Fraction SE 1/4 SE 1/4 NE 1/4		Section Number 4		Township Number T 26 S		Range Number R 34 E/W	
Distance and direction from nearest town or city street address of well if located within city? From Hwy. 50 on north side of Holcomb - 5 M. South, 1 M. West, 6 M. South, 1-1/3 M. West, 1-1/3 M. South, 3,035 ft. north & 150 ft. west									
2 WATER WELL OWNER: RR#, St. Address, Box # : City, State, ZIP Code :		Kenneth, Ralph & David Robinson P. O. Box 222 Holcomb, Kansas 67851				Well #28 Board of Agriculture, Division of Water Resources Application Number: 20,136			
3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX: <div></div>		4 DEPTH OF COMPLETED WELL 430 ft. ELEVATION: Depth(s) Groundwater Encountered 1 ft. 2 ft. 3 ft. WELL'S STATIC WATER LEVEL 210 ft. below land surface measured on mo/day/yr 9/7/04 Pump test data: Well water was ft. after hours pumping gpm Est. Yield gpm: Well water was ft. after hours pumping gpm WELL WATER TO BE USED AS: 1 Domestic 3 Feedlot 5 Public water supply 8 Air conditioning 11 Injection well 2 Irrigation 4 Industrial 6 Oil field water supply 9 Dewatering 12 Other (Specify below) Was a chemical/bacteriological sample submitted to Department? Yes No X ; If yes, mo/day/yr sample was submitted Water Well Disinfected? Yes No X							
5 TYPE OF BLANK CASING USED: 1 Steel 3 RMP (SR) 5 Wrought iron 8 Concrete tile CASING JOINTS: Glued Clamped 2 PVC 4 ABS 6 Asbestos-Cement 9 Other (specify below) Welded XX Blank casing diameter 16 in. to 245 ft. Dia in. to ft. Dia in. to ft. Casing height above land surface 12 in., weight 42.05 lbs./ft. Wall thickness or gauge No. 250 TYPE OF SCREEN OR PERFORATION MATERIAL: 1 Steel 3 Stainless Steel 5 Fiberglass 7 PVC 10 Asbestos-Cement 2 Brass 4 Galvanized Steel 6 Concrete tile 8 RMP (SR) 11 Other (Specify) 12 None used (open hole) SCREEN OR PERFORATION OPENINGS ARE: 1 Continuous slot 3 Mill slot 5 Gauzed wrapped 8 Saw cut 11 None (open hole) 2 Louvered shutter 4 Key punched 6 Wire wrapped 9 Drilled holes 7 Torch cut 10 Other (specify) ft. SCREEN-PERFORATED INTERVALS: From 245 ft. to 430 ft., From ft. to ft. GRAVEL PACK INTERVALS: From 20 ft. to 178 ft., From 238 ft. to 430 ft. From ft. to ft., From ft. to ft.									
6 GROUT MATERIAL: 1 Neat cement 2 Cement grout 3 Bentonite 4 Other Grout Intervals: From 0 ft. to 20 ft., From 278 ft. to 238 ft., From ft. to ft. What is the nearest source of possible contamination: 1 Septic tank 4 Lateral lines 7 Pit privy 10 Livestock pens 14 Abandoned water well 2 Sewer lines 5 Cess pool 8 Sewage lagoon 11 Fuel storage 15 Oil well/Gas well 3 Watertight sewer lines 6 Seepage pit 9 Feedyard 12 Fertilizer storage 16 Other (specify below) Direction from well? How many feet? N/A									
FROM TO LITHOLOGIC LOG FROM TO PLUGGING INTERVALS									
See attached log					RECEIVED				
					SEP 17 2004				
					BUREAU OF WATER				
7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on (mo/day/year) 9/7/04 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's Licence No 208 This Water Well Record was completed on (mo/day/yr) 9/14/04 under the business name of Minter-Wilson Drilling Co., Inc. by (signature) <i>Nora Keller</i>									
INSTRUCTIONS: Use typewriter or ball point pen. PLEASE PRESS FIRMLY and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Bureau of Water, Geology Section, 1000 SW Jackson St., Suite 420, Topeka, Kansas 66612-1367. Telephone 785-296-5522. Send one to WATER WELL OWNER and retain one for your records. Fee of \$5.00 for each constructed well.									

*The
Professionals*

MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box A • GARDEN CITY, KANSAS 67846

Robinson Ranch
Finney County
8/20/04

Location: NE $\frac{1}{4}$ 4-26-34 - From Robinson's Shop - 1 mile south, 2 miles west,
3/4 of a mile south & $\frac{1}{4}$ mile east to pivot
Circle #28
- From pivot - 1,158 ft. east & 264 ft. south

Static Water Level - 210 ft.

Test #5

0' to 1' - Top soil
1' to 3' - Fine sand - loose
3' to 6' - Brown clay
6' to 19' - Fine sand - loose
19' to 43' - Brown sandy clay
43' to 50' - Fine to medium sand & gravel - clay streak
50' to 151' - Medium coarse gravel
151' to 175' - Brown sandy clay
175' to 185' - Fine to medium sand & gravel - clay streak
185' to 197' - Brown sandy clay - small gravel strip
197' to 232' - Fine to medium sand & gravel - 10% clay
232' to 241' - Brown sandy clay - 25% gravel
241' to 264' - Fine to medium sand & gravel
264' to 268' - Fine to medium sand & gravel - hard pull down 200
268' to 275' - Fine to medium sand & gravel
275' to 293' - Brown sandy clay
293' to 302' - Fine to medium sand & gravel
302' to 337' - Brown sandy clay - sand stone streak
337' to 343' - Brown sandy clay - hard pull down 300
343' to 348' - Fine sand - small clay strip
348' to 358' - Fine to medium sand
358' to 363' - Brown clay - small gravel strip
363' to 417' - Brown clay
417' to 419' - Brown rock sand stone - loose
419' to 430' - Yellow clay
430' to 445' - Yellow gray clay - hard pull down 250
445' to 455' - Shale