

[illegible]

*The
Professionals*

MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box A • GARDEN CITY, KANSAS 67846

NAME WHEATLAND ELECTRIC - CIRCLE #G96
COUNTY FINNEY
DATE 9-26-08

LOCATION: SW 1/4 12-26-34 - HOLCOMB LANE SOUTH TO IVANHOE ROAD -
2-1/2 MILES SOUTH, 1/2 MILE WEST,
1/2 MILE NORTH, 3/8THS OF A MILE WEST
FOLLOW CIRCLE - NW EDGE OF CIRCLE

STATIC WATER LEVEL - 225 FT.

TEST #3

0' TO 1' - TOP SOIL
1' TO 27' - BROWN SANDY CLAY
27' TO 59' - BROWN CLAY
59' TO 71' - FINE TO MEDIUM SAND & GRAVEL
71' TO 130' - FINE TO MEDIUM SAND & GRAVEL - SOME COARSE
130' TO 141' - BROWN CLAY
141' TO 166' - FINE TO MEDIUM SAND & GRAVEL - 10% CLAY
166' TO 186' - BROWN SANDY CLAY
186' TO 248' - FINE TO MEDIUM SAND & FINE GRAVEL
248' TO 294' - FINE TO MEDIUM SAND & GRAVEL WITH CLAY STREAKS
294' TO 319' - BROWN CLAY
319' TO 334' - BROWN SANDY CLAY
334' TO 374' - BROWN CLAY - STICKY
374' TO 389' - BROWN CLAY
389' TO 391' - FINE TO MEDIUM SAND
391' TO 407' - BROWN CLAY WITH STREAKS OF GRAVEL
407' TO 455' - BROWN CLAY
455' TO 457' - BROWN ROCK
457' TO 463' - BROWN YELLOW CLAY
463' TO 467' - YELLOW CLAY
467' TO 485' - SHALE - HARD PULL DOWN