


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Kearny	Fraction NW 1/4 SE 1/4 NW 1/4	Section number 2	Township number T 26 S	Range number R 35 E
2. Distance and direction from nearest town or city: 1/2 east of the Deerfield river bridge, 11 1/2 south, Street address of well location if in city: 1/4 east.			3. Owner of well: Jack Campbell R.R. or street: Lakin, Ks. 67360 City, state, zip code:		
4. Locate with "X" in section below: <div style="text-align: center;">N 1 Mile W  E S 1 Mile</div>			Sketch map:		
5. Type and color of material			6. Bore hole dia. 26 in. Completion date 6-10-77 Well depth 364 ft.		
			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material steel Height: Above surface Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 365 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gage No. 250		
			10. Screen: Manufacturer's name Johnson Type galv. Dia. 16" Slot 3/16 Length 10 ft. Set between 290-300 ft. and 340-350 ft. Perf: 140-290 ft. and 300-340, 350-364 Gravel pack? yes Size range of material 2" down		
			11. Static water level: 110 ft. below land surface Date 1-20-77		
			12. Pumping level below land surfaces: 117 ft. after 2 hrs. pumping 900 g.p.m. 122 ft. after 4 hrs. pumping 1300 g.p.m. Estimated maximum yield 1300 g.p.m.		
			13. Water sample submitted: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date		
			14. Well head completion: 12 Inches above grade <input type="checkbox"/> Pitless adapter		
			15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
16. Nearest source of possible contamination: N/A ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>					
17. Pump: Not installed Manufacturer's name Goulds - US Pump Model number 12 JHC HP 200 Volts 200 Length of drop pipe 200 ft. capacity 1200 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other					
18. Elevation:			19. Remarks: <div style="text-align: center;">(Use a second sheet if needed)</div>		
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Winter-Wilson Drilling Co. 208 Business name Box A Garden City, Ks. License No. 9-30-14 Address Box A Garden City, Ks. Signed [Signature] Date 9-30-14 Authorized representative					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

The
Professionals -

MINTER-WILSON DRILLING CO.
INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

JACK CAMPBELL
LEAVY COUNTY
11-29-76

Location: R. 2-20-35 11 miles south of river road and on
Greenfield lane 1750 Ft. east 1750 Ft. south
Static Water Level- 90'

Test #1

0	21	Fine sand
21	133	Fine to med. sand and gravel
133	141	Brown clay
141	157	Fine to med. sand and gravel 10%
157	185	Brown clay
185	201	Fine to med. sand and gravel
201	247	Brown clay
247	303	Fine to med. sand and gravel
303	336	Brown sandy clay
336	364	Fine to med. sand and fine gravel
364	416	Brown sandy clay
416	425	Brown and yellow clay