


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:		County <b>Kearny</b>	Fraction <b>SE 1/4 NW 1/4 SW 1/4</b>	Section number <b>3</b>	Township number <b>T 26 S</b>	Range number <b>R 35 E</b>
2. Distance and direction from nearest town or city: <b>1/2 east of Deerfield river bridge, 10 south 1 west, 3/4 south.</b>				3. Owner of well: <b>Jim White</b> R.R. or street: <b>Lakin, Ks. 67860</b> City, state, zip code:		
4. Locate with "X" in section below: Sketch map: 				6. Bore hole dia. <b>26</b> in. Completion date <b>6-10-77</b> Well depth <b>366</b> ft.		
5. Type and color of material				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material <b>steel</b> Height: Above or below <b>12</b> in. Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>12</b> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <b>36.87</b> lbs./ft. Dia. <b>16</b> in. to <b>367</b> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <b>250</b>		
				10. Screen: Manufacturer's name <b>Johnson</b> Type <b>galv.</b> Dia. <b>16</b> " Slot/gauge <b>10</b> ft. Length <b>10</b> ft. Set between <b>180-190</b> ft. and <b>270-280</b> ft. Perf: <b>140-180</b> ft. and <b>190-270, 280-366</b> Gravel pack? <b>yes</b> Size range of material <b>3/8" down</b>		
				11. Static water level: <b>94</b> ft. below land surface Date <b>5-2-77</b>		
				12. Pumping level below land surfaces: <b>100</b> ft. after <b>2</b> hrs. pumping <b>1100</b> g.p.m. <b>105</b> ft. after <b>4</b> hrs. pumping <b>1900</b> g.p.m. Estimated maximum yield <b>1900</b> g.p.m.		
				13. Water sample submitted: <b>mo./day/yr.</b> <b>Yes</b> <input checked="" type="checkbox"/> <b>No</b> <input type="checkbox"/> Date <b>5-2-77</b>		
				14. Well head completion: <b>12</b> inches above grade <input type="checkbox"/> Pitless adapter		
				15. Well grouted? <b>yes</b> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <b>0</b> ft. to <b>10</b> ft.		
				16. Nearest source of possible contamination: <b>N/A</b> ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <b>Yes</b> <input checked="" type="checkbox"/> <b>No</b> <input type="checkbox"/>		
(Use a second sheet if needed)				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name <b>Goulds-US Pump</b> Model number <b>12 JHC</b> HP <b>125</b> Volts <b>200</b> Length of drop pipe <b>200</b> ft. capacity <b>1200</b> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Minter-Wilson Drilling Co. 208</b> Business name <b>Box A Garden City, Ks.</b> License No. <b>230-77</b> Address <b>Box A Garden City, Ks.</b> Signed <b>[Signature]</b> Date <b>5-2-77</b> Authorized representative			

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

*The*  
*Refinements*

**MINTER-WILSON DRILLING CO.**  
INCORPORATED

Irrigation  
and Domestic  
Water Systems  
Complete Installation  
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

JIM WHITE  
KEARNY COUNTY  
2/3/77

Location: 3 -26- 35 300 Ft. south of pivot  
Static Water Level- 100'

Test #2

0	3	Top soil
3	34	Fine sand
34	49	Brown clay
49	66	Fine to med. sand and gravel
66	81	Coarse to med. gravel
81	102	Fine to med. sand and gravel
102	146	Med. to coarse sand and gravel
146	161	Fine to med. sand and gravel
161	194	Med. to coarse sand and gravel
194	205	Fine to med. sand and gravel 10% clay
205	246	Brown clay
246	261	Fine to med. sand and gravel 20% clay
261	293	Fine to med. sand and gravel
293	306	Fine to med. sand and gravel 10% clay
306	321	Fine to med. sand and gravel 20% clay
321	329	Brown clay
329	351	Brown sandy clay
351	366	Fine sand
366	398	Brown sandy clay
398	406	Brown and yellow clay
406	410	Shale

TD. 366'