

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620


1 Location of well:	County Kearny	Township name Southside	Fraction NE 1/4 or SW 1/4	Section number 4	Town number T-26S	Range number R-35-W
---------------------	-------------------------	-----------------------------------	-------------------------------------	----------------------------	-----------------------------	-------------------------------

Distance and direction from nearest town or city: **12 miles South of**
Street address of well location if in city: **Deerfield, Kansas**

3 Owner of well: **White Enterprises**
Address: **Lakin, Kansas**

Locate with "X" in section below:

Sketch map:



4 Well depth: **400** ft. Date of completion **1-31-75**
Well diameter **20** in.

5 ☐ Cable tool ☐ Rotary ☐ Driven ☐ Dug
☐ Hollow rod ☐ Jetted ☐ Bored ☒ Reverse rotary

6 Use: ☐ Domestic ☐ Public supply ☐ Industry
☒ Irrigation ☐ Air conditioning ☐ Commercial
☐ Test well ☐

7 Casing: Material **St.** Height: above **4** below
Threaded ☐ Welded ☒ Surface **12** in.
Diam. **16** in. to **401** ft. depth Drive shoe? ☐ Yes ☒ No
_____ in. to _____ ft. depth

2	Type and color of material	From	To
	Fine Sand	0	28
	Medium Coarse Gravel (Loose)	28	193
	Brown Clay	193	224
	Medium Coarse Gravel, streak of 2% Clay	224	245
	Brown Sandy Clay	245	292
	Fine to Medium Sand & Gravel 10% Clay	292	305
	Brown Sandy Clay	305	354
	Brown Sandy Clay, 10% Gravel Tight	354	363
	Brown Sandy Clay	363	383
	Fine to Medium Sand & Gravel (Loose)	383	400
	Brown Sandy Clay	400	420
	Brown & Yellow Clay (Hard)	420	440
	(use a second sheet if needed)		

8 Screen:
Manufacturer **Johnson Division**
Type **Galv.** Dia. **16"**
Slot **1/8"** Length **20'**
Set between **180** ft. and **190** ft. **380-390**
Perforations: 120-180, 190-310, 390-400
Gravel pack ☒ Yes ☐ No Size range of material **1/2" down**

9 Static water level:
66 ft. below land surface Date **1-31-75**

10 Pumping level below land surfaces:
76 ft. after **3** hrs. pumping **1500** g.p.m.
_____ ft. after _____ hrs. pumping _____ g.p.m.
Estimated maximum yield **1500** g.p.m.

11 Water sample submitted:
☐ Yes ☒ No Date _____

12 Well head completion:
☐ Pitless adapter **12** inches above grade

13 Well grouted? ☒ Yes ☐ No
☐ Neat cement ☐ Bentonite ☒ Clay Puddled
Depth: From **0** ft. to **10** ft.

14 Nearest source of possible contamination: **N/A**
ft. _____ Direction _____ Type _____
Well disinfected upon completion? ☐ Yes ☒ No

15 Pump:
☐ Not installed
Manufacturer's name **FMC-Pearless**
Model number **G103062** HP **100** Volts _____
Length of drop pipe **160** ft. capacity **800** g.p.m.
Type:
☐ Submersible ☒ Turbine
☐ Jet ☐ Reciprocating
☐ Centrifugal ☐ Other

16 Remarks: elevation

Located near center of quarter section

Topography:

- ☐ Hill
☒ Slope
☐ Upland
☐ Valley

Good Well

No possible contamination

No Other Comments!

17 Water well contractor's certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Minter-Wilson Drlg. Co. 200

Business name _____ License No. _____

Address **Box 493 Garden City, Ks.**

Signed **[Signature]** Date **3-12-75**
Authorized representative

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5