


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Kearny	Township name Southside	Fraction NE of NE 1/4	Section number 4	Town number T 26 S	Range number R 35 W
Distance and direction from nearest town or city: 12 miles south of Deerfield, Ks.			3 Owner of well: White Enterprises Address: Lakin, Ks.			
Locate with "X" in section below: N  S 1 Mile			Sketch map:			4 Well depth: 398' ft. Date of completion 1-31-75 Well diameter 26 in.
2 Type and color of material			From	To	5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
Top Soil			0	12	6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>	
Fine Sand			12	25	7 Casing: Material St. Height: above/below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. Diam. 54.2 lbs./ft. 1 10 in. to 590 depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No 10 in. to 590 ft. depth	
Fine to Medium Sand & Gravel (Loose)			25	39	8 Screen: Manufacturer Johnson Division Type Galv. Dia. 10" Slot 1/16 Length 20' Set between 370 ft. and 590 ft. Finings: 120-140, 220-280, 350-510, 390-590 Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 12" down	
Medium Coarse gravel, streak of Clay (loose)			39	136	9 Static water level: 73 ft. below land surface Date 1-31-75	
Brown Sandy Clay			136	215	10 Pumping level below land surfaces: 90 ft. after 5 hrs. pumping 1140 g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield 1200 g.p.m.	
Fine to Medium Sand & Gravel (Hard)			215	230	11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date ____	
Brown Sandy Clay			230	254	12 Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade	
Fine to Medium Sand & Gravel (Loose)			254	274	13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Clay puddled Depth: From 0 ft. to 10 ft.	
Brown White Clay			274	305	14 Nearest source of possible contamination: N/A ft. ____ Direction ____ Type ____ Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
Brown Sandy Clay, streak of Gravel			305	320	15 Pump: <input type="checkbox"/> Not installed Manufacturer's name FMC-Deerless Model number G103064 HP 100 Volts ____ Length of drop pipe 160 ft. capacity 800 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
Brown Sandy Clay			320	350	17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drlg. Co. 200 Business name Box 495 Garden City, Ks. License No. ____ Address Box 495 Garden City, Ks. Signed [Signature] Date 3-12-75 Authorized representative	
Fine to Medium Sand & Gravel (Loose)			350	361		
Brown Clay			361	365		
Yellow Clay (Hard)			398	435		
Shale (Hard)			435	440		
16 Remarks: elevation #14 Located near center of 1/4 Section No Possible Contamination Topography: <input type="checkbox"/> Hill Good Well. <input checked="" type="checkbox"/> Slope No Other Comments! <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5