

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.


T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

USA Baker

CWW Inv. # 11172

1 Location of well:	County Kearney	Township name	Fraction C-NE-SE	Section number 14	Town number 26S	Range number 35W
Distance and direction from nearest town or city: 13 miles south of Deerfield Street address of well location if in city:				3 Owner of well: Sage Drilling Company Rig #5 Address: 500 Bitting Building Wichita, Kansas 67202		
Locate with "X" in section below: 		Sketch map: DEERFIELD 13 so. LOCATION		4 Well depth: 240 ft. Date of completion 3-28-75 Well diameter 9 in.		
2 Type and color of material		From		To		5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
						6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input checked="" type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/> Oil Rig
Surface		0		2		7 Casing: Material PVC Height: above/below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 18 in. Diam. 5 in. to 180 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No 5 in. to 240 ft. depth
Fine sand		2		16		X Screen: Manufacturer Sawed Preferations Type PVC Dia. 5 1/2" Slot/gauze .030 Length 50 Set between 180 ft. and 230 ft. Fittings: 1/8 - 3/16 Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material
Clay		16		36		9 Static water level: 122 ft. below land surface Date 3-28-75
Medium gravel		36		87		10 Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield 50 g.p.m.
Sandy clay		87		106		11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date
Fine sand		106		145		12 Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> 18 inches above grade
Blue Clay		145		175		13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From 88 ft. to 240 ft.
Fine to medium sand		175		240		14 Nearest source of possible contamination: ft. 100 Direction NE Type Oil Well Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
(use a second sheet if needed)						15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
16 Remarks: elevation Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Carlile Water Well 118 Business name License No. Address Box 275, Liberal, Kansas Signed Edward E. Means Date 4-2-75 Authorized representative		

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5