


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Kearny County	Fraction 1/4 1/4 SE 1/4	Section number 19	Township number T 26 S R 35 E/W	Range number
2. Distance and direction from nearest town or city: 12 South of Lakin on Hiway 25, 9 3/4 East, 1/4 North Street address of well location if in city:			3. Owner of well: Walter Fletcher Lakin, KS 67860 R.R. or street: City, state, zip code:		
4. Locate with "X" in section below: N 1 Mile W E S 1 Mile			Sketch map: 		
5. Type and color of material			From	To	6. Bore hole dia. 26 in. Completion date 3-28-79 Well depth 306 ft.
Casing Schedule 0 - 130 Plain 130 - 260 Perf. 260 - 300 Screen 300 - 306 Perf.					7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary
					8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
					9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 1 ft. in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 306 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. .219
					10. Screen: Manufacturer's name Johnson Type Johnson Galv. Dia. 100-16" Slot/gauze <input type="checkbox"/> Length <input type="checkbox"/> Set between <input type="checkbox"/> ft. and <input type="checkbox"/> ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack? yes Size range of material 1/2 to 5/8
					11. Static water level: <input type="checkbox"/> mo./day/yr. 90 ft. below land surface Date 3-1-79
					12. Pumping level below land surfaces: 113 ft. after 2 hrs. pumping 1200 g.p.m. 119 ft. after 4 hrs. pumping 1500 g.p.m. Estimated maximum yield 1500 g.p.m.
					13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>
					14. Well head completion: <input type="checkbox"/> Pitless adapter 1 ft. inches above grade
					15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
					16. Nearest source of possible contamination: ft. <input type="checkbox"/> Direction N/A Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No
					17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Gould 5 stg. 12" Bowl Model number <input type="checkbox"/> HP 125 Volts <input type="checkbox"/> Length of drop pipe 200 ft. capacity 1000 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
18. Elevation:			19. Remarks:		
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley			(Use a second sheet if needed)		
			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter Wilson Drilling Co. 208 Business name License No. 67846 Address Box A, Garden City, KS <i>M. Wilson</i> 3/17/79 Authorized representative Date		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

MINTER-WILSON DRILLING CO.
INCORPORATED

and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box A • GARDEN CITY, KANSAS 67846
January 19, 1979

Walter Fletcher
Kearny County

Location: S. E. $\frac{1}{4}$ 19-26-35
Static Water Level 110
Test # Pivot

	39	Fine Sand
39	101	Med. to coarse gravel (loose)
101	110	Brown Clay
110	136	Med. to coarse gravel (loose)
136	155	Brown Clay
155	169	Fine to med. sand and gravel (loose)
169	239	Brown Clay
239	304	Fine to med. sand and gravel 10% Clay (loose)
304	320	Brown Clay
320	352	Brown Clay & White Rock (hard)
352	365	Brown Sandy Clay streaks of gravel 30% (Fairly loose)
365	374	Brown Clay
374	390	Brown Gray & Yellow Clay with brown rock (hard)

RECEIVED

AUG 23 1979

DIVISION OF ENVIRONMENT
OF & EG SEC.

