

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Kearny County	Fraction NE 1/4 NW 1/4 SE 1/4	Section number 20	Township number T 26 S	Range number R 35 E			
2. Distance and direction from nearest town or city: 12 South of Lakin on Hiway 25, 10 3/4 East, 1/2 North, Offset Street address of well location if in city: 600' north of Pivot		3. Owner of well: Walter Fletcher R.R. or street: Lakin, KS 67860 City, state, zip code:						
<input checked="" type="checkbox"/> Locate with "X" in section below: N 1 Mile W E S 1 Mile		Sketch map:		6. Bore hole dia. 26 in. Completion date 3-28-79 Well depth 309 ft.				
5. Type and color of material		From		To		7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
						8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
						9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 1 ft. in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 309 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. .219		
						10. Screen: Manufacturer's name Johnson Type Johnson Galv. 100-16" Slot/gauze <input type="checkbox"/> Length <input type="checkbox"/> Set between <input type="checkbox"/> ft. and <input type="checkbox"/> ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack? yes Size range of material 1/2 to 5/8		
						<input checked="" type="checkbox"/> Static water level: <input type="checkbox"/> mo./day/yr. 118 ft. below land surface Date 1-25-79		
(Use a second sheet if needed)						12. Pumping level below land surfaces: 198 ft. after 2 hrs. pumping 1000 g.p.m. 220 ft. after 4 hrs. pumping 1300 g.p.m. air Estimated maximum yield 1200 g.p.m.		
						13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>		
						14. Well head completion: <input type="checkbox"/> Pitless adapter 1 ft. Inches above grade		
						15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
						16. Nearest source of possible contamination: ft. <input type="checkbox"/> Direction N/A Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No		
(Use a second sheet if needed)						17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Gould 5 stg. 12" Bowl Model number <input type="checkbox"/> HP 125 Volts <input type="checkbox"/> Length of drop pipe 240 ft. capacity 1000 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
						18. Elevation:	19. Remarks:	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter Wilson Drilling 208 Business name License No. 67846 Address Box A, Garden City, KS Signature [Signature] Date 3/7/79 Authorized representative
						Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		
						Forward the white, blue and pink copies to the Department of Health and Environment		Form WWC-5
						MI-1023		

Phone 276-8269 • P.O. Box A • GARDEN CITY, KANSAS 67846

January 25, 1979

Walter Fletcher
Kearny County

Location: S. E. $\frac{1}{4}$ 20-26-35 offset 600' North of Pivot
Static Water Level - 118

Test #

0	45	
45	92	Med. coarse gravel
92	97	Brown Sandy Clay
97	105	Fine to med. sand 15% Clay
105	110	Brown Sandy Clay
110	119	Fine to med. sand and gravel (loose)
119	157	Brown Sandy Clay
157	172	Brown Sandy Clay 15% Gravel
172	183	Fine to med. sand and gravel 10% Clay (loose)
183	211	Brown Sandy Clay
211	220	Fine to med. sand and gravel (loose)
220	232	Med. coarse gravel 10% Clay (loose)
232	252	Med. coarse gravel (loose)
252	259	Brown Sandy Clay hard
259	277	Fine to med. sand and gravel (loose)
277	290	Fine to med. sand and gravel hard streak
290	309	Med. coarse gravel little tight
309	366	Brown Sandy Clay White Rock hard pull down
366	398	Brown Sandy Clay
398	410	Brown Yellow Clay Brown Rock Hard