


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Kearny County	Fraction 1/4 1/4 SW 1/4	Section number 20	Township number T 26 S	Range number R 35 E/W
2. Distance and direction from nearest town or city: 12 South of Lakin on Hiway 25, 10 1/2 East, 1/2 North, Offset Street address of well location if in city: 300' West of Pivot				3. Owner of well: Walter Fletcher R.R. or street: Lakin, KS 67860 City, state, zip code:		
4. Locate with "X" in section below:		Sketch map:				
						
5. Type and color of material		From	To	6. Bore hole dia. 26 in. Completion date 3-28-79 Well depth 331 ft.		
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 1 ft. in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 331 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. .219		
				10. Screen: Manufacturer's name Johnson Type Johnson Galv. Dia. 100-16" Slot/gauze <input type="checkbox"/> Length <input type="checkbox"/> Set between <input type="checkbox"/> ft. and <input type="checkbox"/> ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack yes Size range of material 1/2 to 5/8		
				11. Static water level: <input type="checkbox"/> mo./day/yr. 118 ft. below land surface Date 2-24-79		
				12. Pumping level below land surfaces: 170 ft. after 2 hrs. pumping 1200 g.p.m. 185 ft. after 4 hrs. pumping 1500 g.p.m. Estimated maximum yield 1500 g.p.m.		
				13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>		
				14. Well head completion: <input type="checkbox"/> Pitless adapter 1 ft. inches above grade		
				15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
				16. Nearest source of possible contamination: ft. <input type="checkbox"/> Direction N/A Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Gould 5 stg. 12" Bowl Model number <input type="checkbox"/> HP 125 Volts <input type="checkbox"/> Length of drop pipe 220 ft. capacity 1000 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
		(Use a second sheet if needed)				
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter Wilson Drilling Co. 208 Business name License No. 67846 Address Box A, Garden City, KS 67846 Signature M. Wilson Date 8/17/79 Authorized representative			
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

Phone 276-8269 • P.O. Box A • GARDEN CITY, KANSAS 67846
January 20, 1979

Walter Fletcher
Kearny County

Location: S. W. 1/4 20-26-35 off set 300' West of Pivot
Static Water Level - 118
Test #A

0	22	Top Soil Fine Sand
22	29	Brown Clay
29	30	Med. coarse Gravel
80	85	Coarse Gravel
85	131	Brown Sandy Clay
131	150	Med. coarse gravel (loose)
150	154	Fine to med. sand and gravel (hard)
154	160	Brown Sandy Clay
160	166	Med. coarse gravel
166	172	Brown Sandy Clay
172	183	Brown Sandy Clay 20% Gravel
183	195	Brown Sandy Clay small streak of gravel
195	202	Fine to med. sand and gravel
202	216	Med. coarse gravel (loose)
216	220	Med. coarse gravel hard streak
220	233	Med. coarse gravel
233	280	Fine to med. sand and gravel streak of coarse gravel (loose)
280	322	Brown Sandy Clay White Hard
322	329	Fine to med. sand fine gravel (loose)
329	363	Brown Sandy Clay Hard
363	370	Yellow Clay Brown Clay hard pull down

RECEIVED

AUG 23 1979

DIVISION OF ENVIRONMENT
OF & EG SEC.