


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Kearny	Fraction NW 1/4 NW 1/4 SW 1/4	Section number 21	Township number T 26 S	Range number R 35 E
2. Distance and direction from nearest town or city: 1/2 east of the Deerfield river bridge, south to the Street address of well location if in city: county line, 2 west, 1/4 northeast.				3. Owner of well: Jim White R.R. or street: Lakin, Ks. 67860 City, state, zip code:		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 26 in. Completion date 6-10-77 Well depth 374 ft.		
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
5. Type and color of material		From		To		8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
						9. Casing: Material steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 375 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 250
						10. Screen: Manufacturer's name Johnson Type galv. Dia. 16" Slot/gauge <input type="checkbox"/> Length 20 ft. Set between 300 ft. and 320 ft. Perf: 180-300 ft. and 320-374 ft. Gravel pack? yes Size range of material 3/4" down
						11. Static water level: <input type="checkbox"/> mo./day/yr. 104 ft. below land surface Date 2-26-77
						12. Pumping level below land surfaces: 139 ft. after 2 hrs. pumping 300 g.p.m. 152 ft. after 4 hrs. pumping 1200 g.p.m. Estimated maximum yield 1200 g.p.m.
						13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>
						14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade
						15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
						16. Nearest source of possible contamination: N/A ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
						17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Goulds - US Pump Model number 12 JHC HP 125 Volts <input type="checkbox"/> Length of drop pipe 200 ft. capacity 1200 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Winter-Wilson Drilling Co. 208 Business name License No. <input type="checkbox"/> Address Box A Garden City, Ks. <i>[Signature]</i> 9-30-77 Authorized representative Date		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

The
Professional

MINTER-WILSON DRILLING CO.
INCORPORATED

Installation
and Dewatering
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

JIM WHITE
NEARBY COUNTY
2/3/77

Location: " 21-26-35 300 Ft. southeast of pivot on 21
Test:

Static Water Level- 150

Test #4

0	2	Top soil
2	33	Fine sand
33	56	Fine to med. sand and gravel
56	67	Med. to coarse gravel
67	91	Fine to med. sand and gravel
91	93	Med. to coarse gravel
93	110	Brown clay
110	131	Blue clay
131	135	Brown clay
135	161	Fine to med. sand and gravel
161	213	Brown clay
213	245	Fine to med. sand and gravel (1" clay)
245	327	Fine to med. sand and gravel
327	365	Brown sandy clay
365	374	Fine to med. sand and gravel
374	399	Brown sandy clay
399	405	Brown and yellow clay
405	410	Shale

T.S. 3/4