

USE TYPEWRITER OR BALL
POINT PEN. PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Kearny	Fraction XX NE 1/4	Section number 29	Township number T 26 S R 35	Range number 35
2. Distance and direction from nearest town or city: 1 1/2 S. & 2 1/4 W. of Deerfield Street address of well location if in city:				3. Owner of well: Jon Fort R.R. or street: City, state, zip code: Ulysses, KS 67880		
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile		Sketch map: Well drilled 4-28-76		6. Bore hole dia. 26 in. Completion date 5-22-76 Well depth 422 ft.		
5. Type and color of material		From	To	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
See attachment				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material Steel Height Above ground Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP 16 <input type="checkbox"/> PVC <input type="checkbox"/> Weight 31 lbs./ft. Dia. 16 in. to 422 ft. depth Wall Thickness: inches or Dia. 16 in. to 422 ft. depth gage No. 188		
				10. Screen: Manufacturer's name Brown Type Louvered Dia. 16" Slot/gauze 1/8" Length 150' Set between 290 ft. and 420 ft. 190 ft. and 210 ft. Gravel pack? Yes Size range of material 1/4 x 1/8		
				11. Static water level: 118 ft. below land surface Date 5-3-76		
				12. Pumping level below land surfaces: 142 ft. after 1420 g.p.m. ft. after 1420 g.p.m. Estimated maximum yield 1420 g.p.m.		
				13. Water sample submitted: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date 5-3-76		
				14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade		
				15. Well grouted? Yes With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
				16. Nearest source of possible contamination: None observed ft. None Direction None Type None Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Johnston Model number 14AC HP 1 Volts 115 Length of drop pipe 225 ft. capacity 14 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Henkle Drlg. & Supply 145 Business name Box 639 Garden City, KS License No. 145 Address J. Henkle Signed J. Henkle Date 6-2-76 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

DRILLERS TEST LOG

CUSTOMERS NAME Jon Fort DATE 3-11-76
STREET ADDRESS _____ TEST # 2 E. Log Hole
CITY & STATE Ulysses, Kansas DRILLER Lee
COUNTY Kearny QUARTER NE SECTION 29 TOWNSHIP 26 RANGE 35
LOCATION 750 Ft. East of Pivot and Test # 1

WELL LOCATION

	DRILLED		FOOTAGE		STATIC WATER LEVEL
%	FROM	PAY	TO	PROPOSED WELL DEPTH	
	0		18	Fine sand, loose.	
	18		22	Sandy clay	
	22		46	Sand fine, med., very few sandy clay st.	
	46		67	Brown clay, some white clay, few sand st.	
	67		80	Sand fine, med. coarse, small to med. gravel. Few clay t. Used water.	
75	80	67	207	Sand fine med. coarse, small to med. to large gravel. Used water. Very rough in places. Few cobblestones	
	207		230	Brown clay, few ledges and sand st.	
	230		287	Brown clay ledges, few broken rock	
				Few sand st.	
	287		307	Blue clay and ledges.	
	307		314	Brown clay, ledges, sand st.	
30	314	4	318	Sand fine med. coarse, small gravel. Clay st.	
	318		323	Brown clay, sand st.	
50	323	12	335	Sand fine med. coarse, small gravel. Clay st.	
	335		340	Brown clay sand fine med. coarse, mixed	
50	340	15	355	Sand fine med. coarse, small to few, med. gravel. Clay st.	
	355		364	Brown sand st.	
40	364	10	374	Sand fine med. coarse, few, small gravel. Caly st.	
	374		380	Brown clay, ledges a lot of sand st.	
40	380	10	390	Sand fine med. coarse, some, small gravel. Few clay st.	
	390		394	Brown clay, sand st.	
45	394	13	407	Sand fine med. coarse; small gravel. Very few med. clay st.	
	407		415	Brown clay, limerock ledges. sand st.	
40	415	5	420	Sand fine med. coarse, a little clay	
	420		450	Brown clay, sand st. Sticky in places.	
	450		460	Brown clay, yellow st.	
				TOTAL DEPTH OF WELL 422 Ft.	

HENKLE DRILLING & SUPPLY CO., INC.

GARDEN CITY, KANSAS
Phone 276-3278

SUBLETTE, KANSAS
Phone 675-4311

TEST HOLES	DOMESTIC WELLS	STOCK WELLS	IRRIGATION & INDUSTRIAL WELLS
------------	----------------	-------------	-------------------------------