


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Kearny	Fraction Center of 1/4 1/4 NW 1/4	Section number 29	Township number T 26 S	Range number R 35 W
2. Distance and direction from nearest town or city: 13 1/4 S. & 2 3/4 W. of Deerfield Street address of well location if in city:			3. Owner of well: Brad Fort R.R. or street: Ulysses, KS 67880 City, state, zip code:			
4. Locate with "X" in section below: 			Sketch map: Well drilled 4-30-76			6. Bore hole dia. 26 in. Completion date 5-26-76 Well depth 363 ft.
5. Type and color of material			From	To	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
See attachment					8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
					9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 31 lbs./ft. Dia. 16 in. to 363 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 188	
					10. Screen: Manufacturer's name Brown Type Louvered Dia. 16 " Slot/gauze 1/8 " Length 80 " Set between 280 ft. and 360 ft. Gravel pack? Yes Size range of material 1/4 x 1/8	
					11. Static water level: 155 ft. below land surface Date 5-5-76	
					12. Pumping level below land surfaces: 206 ft. after <input type="checkbox"/> hrs. pumping 1435 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <input type="checkbox"/> g.p.m.	
					13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>	
					14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade	
					15. Well grouted? Yes With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
					16. Nearest source of possible contamination: None observed ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
					17. Pump: Manufacturer's name Johnston Model number 14AC HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe 245 ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
			(Use a second sheet if needed)			
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Henkle Drlg. & Supply 145 Business name Box 639 Garden City, KS License No. 6-2-76 Address 6-2-76 Signed John Henkle Date 6-2-76 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

DRILLERS TEST LOG

CUSTOMERS NAME Brad Fort DATE 2-27-76
 STREET ADDRESS 916 N. Durham TEST # 1 E. Log hole
 CITY & STATE Ulysses, KS DRILLER Lee
 COUNTY Kearny QUARTER NW SECTION 29 TOWNSHIP 26 RANGE 35

LOCATION Approximately 25' West of Pivot

%	FOOTAGE			WELL LOCATION	
	DRILLED From	Pay To		Description of Strata	Static Water Level Proposed Well Depth
	0		36	Sand fine med. Loose	
	36		51	Sand fine med. Loose. 1 sandy clay st. at 36'. Used Water.	
	51		60	Brown clay, ledges, few sand st.	
	60		80	Sand fine med. coarse, small to med. gravel. Used water.	
	80		138	Sand fine med. coarse, small to med. gravel and large, very rough in places. Used water. Very, very rough 108' to 117'.	
	138		159	Brown clay, ledges, sand st.	
45	159	9	168	Sand fine med. coarse, small gravel, clay st.	
	168		185	Brown clay, few ledges, few sand st. A little sticky in places.	
	185		205	Brown clay, few gray st. Sticky in places. Few ledges, few sand st.	
	205		222	Brown clay, sand st., few broken white rock, few ledges	
	222		253	Blue clay, few ledges	
	253		264	Brown clay, ledges, few sand st., some hard ledges	
65	264	30	294	Sand fine, med. course, small gravel to med. gravel. Rough in places. Used water. Very few clay st.	
	294		299	Brown clay, ledges and sand st.	
55	299	16	315	Sand fine med. coarse, small gravel, very few clay st., one at 309'	
	315		324	Brown clay, few ledges, few sand st. Clay a little sticky in places.	
55	324	10	334	Sand fine med. coarse, small gravel, very few med. very few clay st.	
	334		355	Brown clay, broken rock, sand st.	
50	355	5	360	Sand fine med. coarse, few small gravel, few small white rock	
	360		405	Brown clay, very sticky in places, very few ledges or sand st.	
	405		420	Soap st., yellow st., very sticky, very few brown rock st.	
		70		TOTAL DEPTH OF WELL 363 FT.	
				Set up rig South; dig pit on West. Location very sandy!	

GARDEN CITY, KANSAS HENKLE DRILLING & SUPPLY CO., INC. SUBLETTE, KANSAS
 PHONE 276-3278 IRRIGATION HEADQUARTERS PHONE 675-4311

TEST HOLES*****STOCK WELLS*****IRRIGATION AND INDUSTRIAL WELLS*****