


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health  
(Water Well Contractors)  
Forbes-Bldg. 740  
Topeka, Kansas 66620

1 Location of well:	County <b>Kearny</b>	Township name	Fraction <b>Center of SE 1/4</b>	Section number <b>33</b>	Town number <b>T 26 S</b>	Range number <b>R 35 W</b>
Distance and direction from nearest town or city: <b>15 south &amp; 1 1/4 west of Deerfield</b> Street address of well location if in city:				3 Owner of well: <b>Clifford Fort</b> Address: <b>Ulysses, Kansas</b>		
Locate with "X" in section below: N  S 1 Mile		Sketch map: <b>Well drilled 6-4-75</b>		4 Well depth: <b>410</b> ft. Date of completion <b>6-21-75</b> Well diameter <b>26</b> in.		
2 Type and color of material		From		To		5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary
						6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>
						7 Casing: Material <b>Steel</b> Height <b>above</b> below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>12</b> in. Diam. <b>16</b> in. to <b>410</b> ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Weight <b>36</b> lbs./ft.
						8 Screen: Manufacturer <b>Brown</b> Type <b>Louvered</b> Dia. <b>16"</b> Slot/gauze <b>1/8"</b> Length <b>140'</b> Set between <b>220</b> ft. and <b>260</b> ft. <b>280</b> & <b>300'</b> Fittings: <b>330'</b> & <b>410'</b> <b>1/4</b> to <b>1/8"</b> Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material <b>1/8"</b>
						9 Static water level: <b>143</b> ft. below land surface Date <b>6-11-75</b>
						10 Pumping level below land surfaces: <b>169</b> ft. after <b>1425</b> g.p.m. ft. after <b>1425</b> g.p.m. Estimated maximum yield <b>1425</b> g.p.m.
						11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <b>6-11-75</b>
						12 Well head completion: <b>12</b> <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade
						13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From <b>0</b> ft. to <b>10</b> ft.
						14 Nearest source of possible contamination: ft. <b>none</b> Direction <b>observed</b> Type <b>observed</b> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
15 Pump: Manufacturer's name <b>Johnston</b> Model number <b>14AC</b> HP <b>1425</b> Volts <b>1425</b> Length of drop pipe <b>225</b> ft. capacity <b>1425</b> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		16 Remarks: elevation  Topography: <input type="checkbox"/> Hill <b>Rolling</b> <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Henkle Drilling &amp; Supply</b> <b>145</b> Business name License No. Address <b>Box 639 Garden City, KS</b> Signed <b>James H. Henkle</b> Date <b>7-11-75</b> Authorized representative		

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5

# DRILLERS TEST LOG

CUSTOMERS NAME	Clifford Fort	DATE	5-21-75
STREET ADDRESS		TEST #1	E-Log 425 ft.
CITY & STATE	Ulysses, KS	DRILLER	Rector
COUNTY	Kearny	QUARTER SE	SECTION 33 TOWNSHIP 26 RANGE 35

**LOCATION** In center of  $\frac{1}{4}$  & 18 ft. E. of Pivot

				WELL LOCATION
%	DRILLED from	PAY	FOOTAGE to	Static Water Level Proposed Well Depth
	0		8	Sand
	8		65	Brown sandy clay & sand.
	65		147	Sand fine to med coarse, small gravel & few cobbles.
	147		170	Brown sandy clay, sand & gravel.
45	170	10	180	Sand fine to med coarse, small gravel, few clay sts., & used water.
70	180	76	256	Sand fine to med coarse, small coarse & small gravel, (loose), used a lot of water.
	256		275	Brown clay, limerock, & sand.
75	275	25	300	Sand fine to med coarse, small gravel, few clay & limerock sts., drilled fairly loose, used a lot of water.
	300		330	Brown clay, limerock, & med coarse gravel sts.
70	330	16	346	Sand fine to med coarse, small gravel, loose, used water.
	346		390	Brown clay, limerock, & sand.
65	390	18	408	Sand fine to med coarse, small coarse, & few tiny white rock, used lots of water.
	406		440	Brown sandy clay & sand.
	440		460	Sticky brown clay.
				Total Depth of Well - 410 ft.
				Set up face northeast southwest Pit on east
				Power unit face north Discharge face west

GARDEN CITY, KANSAS      HENKLE DRILLING & SUPPLY CO., INC.      SUBLETTE, KANSAS  
PHONE 276-3278      IRRIGATION HEADQUARTERS      PHONE 675-4311  
EST HOLES\*\*\*\*\*STOCK WELLS\*\*\*\*\*IRRIGATION AND INDUSTRIAL WELLS\*\*\*\*\*