


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Kearny	Township name Center of SW	Fraction 1/4	Section number 33	Town number T 26 S	Range number R 35 W
Distance and direction from nearest town or city: 15 south & 1 3/4 west of Deerfield				3 Owner of well: Clifford Fort		
Street address of well location if in city:				Address: Ulysses, Kansas		
Locate with "X" in section below: 		Sketch map: Well drilled 6-5-75		4 Well depth: 408 ft. Date of completion 7-10-75 Well diameter 26 in.		
2 Type and color of material See Attachment		From		To		5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary
						6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>
						7 Casing: Material Steel Height: above below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. Diam. 16 in. to 408 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Weight 36 lbs./ft.
						8 Screen: Manufacturer Brown Type Louvered Dia. 16" Slot/gauze 1/8" Length 130' Set between 228 ft. and 248 ft. 288' & 368' Fittings: 408' & 438' 1/4 to 1/8" Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material
						9 Static water level: 144 ft. below land surface Date 6-16-75
						10 Pumping level below land surfaces: 166 ft. after 1450 g.p.m. ft. after 1450 g.p.m. Estimated maximum yield 1450 g.p.m.
						11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date
						12 Well head completion: 12 <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade
						13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From 0 ft. to 10 ft.
						14 Nearest source of possible contamination: none observed ft. Direction Type Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
15 Pump: Manufacturer's name Johnston Model number 14AC HP 1450 Volts Length of drop pipe 225 ft. capacity 1450 g.m.p. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		16 Remarks: elevation Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope Rolling <input type="checkbox"/> Upland <input type="checkbox"/> Valley		17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Henkle Drilling & Supply 145 Business name License No. Address Box 639 Garden City, KS Signed John Henkle Date 7/21/75 Authorized representative		

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5

DRILLERS TEST LOG

CUSTOMERS NAME Clifford Fort DATE 5-22-75
STREET ADDRESS _____ TEST # 1 E-Log - 440 ft.
CITY & STATE Ulysses, KS DRILLER Rector
COUNTY Kearny QUARTER SW SECTION 33 TOWNSHIP 26 RANGE 35

LOCATION In center of $\frac{1}{4}$ & 18 ft. west of Pivot Point

[illegible]

GARDEN CITY, KANSAS HENKLE DRILLING & SUPPLY CO., INC. SUBLETTE, KANSAS
PHONE 276-3278 IRRIGATION HEADQUARTERS PHONE 675-4311
BEST HOLES*****STOCK WELLS*****IRRIGATION AND INDUSTRIAL WELLS*****