

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

CWW Inv. #12486

See 25-4

1. Location of well:	County Kearney	Fraction 1/4 NE 1/4 NE 1/4	Section number 5	Township number T 26 S R 36 E/W	Range number
2. Distance and direction from nearest town or city: North of Ulysses appr. 2 1/2 mi. to feedlot - 1/2 mi. Ea. - 4 mi. So.			3. Owner of well: Zenith Drilling Company R.R. or street: Suite 600, 200 West Douglas City, state, zip code: Wichita, Kansas 67202		
4. Locate with "X" in section below: <div style="display: flex; align-items: center;"> <div style="margin-right: 10px;"> <p>Sketch map:</p> </div> </div>			6. Bore hole dia. 9 in. Completion date 7/13/76 Well depth 200 ft.		
5. Type and color of material			7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input checked="" type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input checked="" type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material <input type="checkbox"/> Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 28 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 2.78 lbs./ft. Dia. 5 in. to 115 ft. depth Wall Thickness: inches or Dia. 5 in. to 200 ft. depth gauge No. 265		
			10. Screen: Manufacturer's name Sawed perf. Type PVC Dia. 5 in. Slot/gauze .030 Length 80 ft. Set between 115 ft. and 195 ft. Gravel pack? yes Size range of material 1/8-3/16		
			11. Static water level: 80 ft. below land surface Date 7/13/76 mo./day/yr.		
			12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield 60 g.p.m.		
			13. Water sample submitted: ____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date ____		
			14. Well head completion: <input type="checkbox"/> Pitless adapter 28 inches above grade		
			15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
			16. Nearest source of possible contamination: ft. 100 Direction NE Type oil well Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:			19. Remarks:		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Carlile Water Well Service, 118 Business name Box 275 Liberal, Ks. License No. ____ Address Edward E. Means Date 7/30/76 Signed Edward E. Means Authorized representative		

26 360 5 NE 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5