

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Kearny County	Section NW 1/4 NE 1/4 SW 1/4	Section number 14	Township number T 26 S	Range number R 36
2. Distance and direction from nearest town or city: 11 South of Lakin on Hiway 25, 7 1/2 East, 1/2 North, 300' North-east of Pivot			3. Owner of well: Walter Fletcher R.R. or street: Lakin, KS 67860 City, state, zip code:		
X. Locate with "X" in section below: N W E S 1 Mile Sketch map: 			6. Bore hole dia. 26 in. Completion date 3-28-79 Well depth 308 ft.		
5. Type and color of material			7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 1 ft. in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia 16 in. to 308 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. .219		
			10. Screen: Manufacturer's name Johnson Type Johnson Galv. D. 100-16" Slot/gauze <input type="checkbox"/> Length <input type="checkbox"/> Set between <input type="checkbox"/> ft. and <input type="checkbox"/> ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack yes Size range of material 1/4 to 5/8		
			11. Static water level: <input type="checkbox"/> mo./day/yr. 66 ft. below land surface Date 2-13-79		
(Use a second sheet if needed)			12. Pumping level below land surfaces: 176 ft. after 2 hrs. pumping 1000 g.p.m. 176 ft. after 4 hrs. pumping 1200 g.p.m. Estimated maximum yield 1200 g.p.m.		
			13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>		
			14. Well head completion: <input type="checkbox"/> Pitless adapter 1 ft. Inches above grade		
			15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
			16. Nearest source of possible contamination: ft. <input type="checkbox"/> Direction N/A Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No		
(Use a second sheet if needed)			17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Could 5 stg. 12" Bowl Model number <input type="checkbox"/> HP 125 Volts <input type="checkbox"/> Length of drop pipe 220 ft. capacity 1000 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter Wilson Drilling Co. 208 Business name License No. <input type="checkbox"/> Address Box A, Garden City, KS 67846 Signed [Signature] Date 8/17/79 Authorized representative		
			18. Elevation:		
			19. Remarks:		
			Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

January 24, 1979

Walter Fletcher
Kearney CountyLocation: S. W. $\frac{1}{4}$ 14-26-36 -C- 300' Northeast of Pivot
Static Water Level - 100
Test #

U	16	Sand
16	51	Med. to coarse gravel (loose)
51	65	Brown Clay
65	125	Blue Clay
125	140	Fine to med. sand and gravel 15% Clay (loose)
140	151	Fine to med. sand and gravel 10% Clay (loose)
151	155	Brown Sandy Clay 30% Gravel
155	205	Brown Sandy Clay
205	212	Fine to med. sand and gravel 15% Clay (loose) (Small hard streaks)
212	255	Fine to med. sand and gravel 10% Clay (loose)
255	277	Brown Sandy Clay
277	290	Fine to med. sand and gravel 10% Clay (loose)
290	308	Fine to med. sand and gravel 15% Clay (loose)
308	316	Brown & Gray Clay (tight) (hard streaks)
316	330	Brown Gray & Yellow Clay (hard)

T. D. 308'

RECEIVED

AUG 23 1979

DIVISION OF ENVIRONMENT
OF & EG SEC.Pay Last Amount In This Column 