

1 LOCATION OF WATER WELL		Fraction		Section Number		Township Number		Range Number					
County: Kearny		1/4 1/4 SE 1/4		21		T 26 S		R 36 E W					
Distance and direction from nearest town or city? Lakin south at county line 6 East at school house, 2 North first on west side of road													
2 WATER WELL OWNER: Earl Berlier RR#, St. Address, Box #: Box 302 City, State, ZIP Code: Lakin, KS 67860 Board of Agriculture, Division of Water Resources Application Number:													
3 DEPTH OF COMPLETED WELL. 285 ft. Bore Hole Diameter. 9 7/8 in. to 285 ft. and in. to ft.													
Well Water to be used as: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Feedlot <input type="checkbox"/> Oil field water supply <input type="checkbox"/> Air conditioning <input type="checkbox"/> Injection well <input type="checkbox"/> Irrigation <input type="checkbox"/> Industrial <input type="checkbox"/> Lawn and garden only <input type="checkbox"/> Dewatering <input type="checkbox"/> Other (Specify below) <input type="checkbox"/> Observation well													
Well's static water level 140' ft. below land surface measured on month day year													
Pump Test Data - None : Well water was ft. after hours pumping. gpm Est. Yield gpm: Well water was ft. after hours pumping. gpm													
4 TYPE OF BLANK CASING USED: <input checked="" type="radio"/> Steel <input type="radio"/> RMP (SR) <input type="radio"/> Wrought iron <input type="radio"/> Concrete tile Casing Joints: Glued Clamped <input type="radio"/> PVC <input type="radio"/> ABS <input type="radio"/> Asbestos-Cement <input type="radio"/> Other (specify below) Welded <input checked="" type="checkbox"/> <input type="radio"/> Fiberglass Threaded													
Blank casing dia. 6 5/8 in. to 0 - 246 ft. Dia in. to ft. Dia in. to ft.													
Casing height above land surface. 12 in. weight 12.8 lbs./ft. Wall thickness or gauge No. 188													
TYPE OF SCREEN OR PERFORATION MATERIAL: <input checked="" type="radio"/> Steel <input type="radio"/> Stainless steel <input type="radio"/> Fiberglass <input type="radio"/> RMP (SR) <input type="radio"/> Asbestos-cement <input type="radio"/> Brass <input type="radio"/> Galvanized steel <input type="radio"/> Concrete tile <input type="radio"/> ABS <input type="radio"/> Other (specify) <input type="radio"/> None used (open hole)													
Screen or Perforation Openings Are: <input type="radio"/> Continuous slot <input type="radio"/> Mill slot <input type="radio"/> Gauzed wrapped <input type="radio"/> Saw cut <input type="radio"/> None (open hole) <input type="radio"/> Louvered shutter <input type="radio"/> Key punched <input checked="" type="radio"/> Wire wrapped <input type="radio"/> Drilled holes <input checked="" type="radio"/> Torch cut <input type="radio"/> Other (specify)													
SCREEN Perforation Dia. 6 5/8 in. to 246-286 ft. Dia in. to ft. Dia in. to ft.													
SCREEN Perforated Intervals: From 246 ft. to 286 ft. From ft. to ft. From ft. to ft.													
Gravel Pack Intervals: From 10 ft. to 285 ft. From ft. to ft. From ft. to ft.													
5 GROUT MATERIAL: <input type="radio"/> Neat cement <input checked="" type="radio"/> Cement grout <input type="radio"/> Bentonite <input type="radio"/> Other													
Grouted Intervals: From 0 ft. to 10 ft. From ft. to ft. From ft. to ft.													
What is the nearest source of possible contamination: <input type="radio"/> Septic tank <input type="radio"/> Cess pool <input type="radio"/> Sewage lagoon <input type="radio"/> Fuel storage <input type="radio"/> Abandoned water well <input type="radio"/> Sewer lines <input type="radio"/> Seepage pit <input type="radio"/> Feed yard <input type="radio"/> Fertilizer storage <input type="radio"/> Oil well/Gas well <input type="radio"/> Lateral lines <input type="radio"/> Pit privy <input type="radio"/> Livestock pens <input type="radio"/> Insecticide storage <input type="radio"/> Other (specify below) <input checked="" type="radio"/> Watertight sewer lines N/A Pasture													
Direction from well How many feet ? Water Well Disinfected? Yes No <input checked="" type="checkbox"/>													
Was a chemical/bacteriological sample submitted to Department? Yes No <input checked="" type="checkbox"/> If yes, date sample was submitted month day year: Pump Installed? Yes No <input checked="" type="checkbox"/>													
If Yes: Pump Manufacturer's name Model No. HP Volts													
Depth of Pump Intake ft. Pumps Capacity rated at gal./min.													
Type of pump: <input type="radio"/> Submersible <input type="radio"/> Turbine <input type="radio"/> Jet <input type="radio"/> Centrifugal <input type="radio"/> Reciprocating <input type="radio"/> Other													
6 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was <input checked="" type="radio"/> constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on May month 19 day 1981 year and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 208 This Water Well Record was completed on August month 24 day 1982 year under the business name of Minter Wilson Drilling Co., Inc. by (signature) <i>Minter Wilson</i>													
7 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:		FROM		TO		LITHOLOGIC LOG		FROM		TO		LITHOLOGIC LOG	
						Test log attached							
ELEVATION:													
Depth(s) Groundwater Encountered 1. ft. 2. ft. 3. ft. 4. ft. (Use a second sheet if needed)													

INSTRUCTIONS: Use typewriter or ball point pen, *please press firmly* and **PRINT** clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Water Well Contractors, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.

The Professionals

MINTER-WILSON DRILLING CO.
INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box A • GARDEN CITY, KANSAS 67846

EARL BERLIER
KEARNY COUNTY
5/18/81

Location: Lakin south at county line 6 miles east at school
house 2 miles north first on west side of road

Static Water Level - 140'

Test #

0	55	Fine Sand
55	77	Brown Sandy Clay
77	100	Fine to Med. Sand and Gravel
100	282	Med. Coarse Gravel
282	290	Brown Sandy Clay

T. D. 286'

RECEIVED

OCT 04 1982

DIVISION OF ENVIRONMENT
OF