


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:	County <b>Kearny County</b>	Fraction <b>1/4 1/4 NW 1/4</b>	Section number <b>22</b>	Township number <b>T 26 S R 36 E/W</b>	Range number
2. Distance and direction from nearest town or city: <b>on Hiway 25, 6 1/2 East, 1/2 South, 30' North of</b> Street address of well location if in city: <b>Pivot</b>		3. Owner of well: <b>Walter Fletcher</b> <b>Lakin, KS 67860</b> City, state, zip code:			
4. Locate with "X" in section below: N W E S 1 Mile		Sketch map: 		6. Bore hole dia. <b>26</b> in. Completion date <b>3-28-79</b> Well depth <b>238</b> ft.	
5. Type and color of material		From	To	7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
Casing Schedule				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
0 - 120 Plain				9. Casing: Material <b>Steel</b> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>1 ft.</b> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <b>36.87</b> lbs./ft. Dia. <b>16</b> in. to <b>238</b> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <b>.219</b>	
120 - 195 Perf.				10. Screen: Manufacturer's name <b>Johnson</b> Type <b>Johnson Galv</b> dia. <b>100-16"</b> Slot/gauze <input type="checkbox"/> Length <input type="checkbox"/> Set between <input type="checkbox"/> ft. and <input type="checkbox"/> ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack? <b>yes</b> size range of material <b>1/2 to 5/8</b>	
195 - 235 Screen				11. Static water level: <input type="checkbox"/> mo./day/yr. <b>98</b> ft. below land surface Date <b>2-23-79</b>	
235 - 238 Perf.				12. Pumping level below land surfaces: <b>105</b> ft. after <b>2</b> hrs. pumping <b>1200</b> g.p.m. <b>107</b> ft. after <b>4</b> hrs. pumping <b>1500</b> g.p.m. Estimated maximum yield <b>1500</b> g.p.m.	
				13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>	
				14. Well head completion: <input type="checkbox"/> Pitless adapter <b>1 ft.</b> inches above grade	
				15. Well grouted? <b>yes</b> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <b>0</b> ft. to <b>10</b> ft.	
				16. Nearest source of possible contamination: ft. <input type="checkbox"/> Direction <b>N/A</b> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No	
				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name <b>Gould 5 stg. 12" Bowl</b> Model number <input type="checkbox"/> HP <b>125</b> Volts <input type="checkbox"/> Length of drop pipe <b>180</b> ft. capacity <b>1000</b> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Minter Wilson Drilling Co. 208</b> Business name License No. <b>1</b> Address <b>Box A, Garden City, KS 67846</b> Signed <b>M. Wilson</b> Date <b>3/17/79</b> Authorized representative	
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

Phone 276-8269

P.O. Box A

GARDEN CITY, KANSAS 67840

January 10, 1979

Walter Fletcher

Kearny County

Location: N. W.  $\frac{1}{4}$  22-26-36 From Jaeger Farm  $\frac{1}{2}$  South,  $\frac{1}{2}$  West  
 $\frac{3}{4}$  South, Back East to Pivot, 30' North of Pivot

Static Water Level - 100

Test #1

0	35	Top Soil Fine Sand
35	75	Fine to med. sand and gravel streak of coarse gravel
75	98	Blue Clay
98	127	Fine to med. sand and gravel streak of coarse gravel small hard streak
127	139	Brown Clay sticky
139	215	Fine to med. sand and gravel streaks of coarse gravel (loose)
215	234	Med. Coarse Gravel (loose)
234	307	Brown Sandy Clay
307	320	Brown Sandy Clay 10% Brown Rock Hard
320	331	Yellow Clay hard
331	335	Shale Hard

RECEIVED

AUG 23 1979

DIVISION OF ENVIRONMENT  
OF & EG SEC.

Pay Last Amount in This Column

Pay Last Amount in This Column