


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:		County <b>Kearny</b>	Fraction <b>NE 1/4 SE 1/4 SW 1/4</b>	Section number <b>26</b>	Township number <b>T 26 S</b>	Range number <b>R 36 E</b>
2. Distance and direction from nearest town or city: <b>South of Lakin on Hiway 25 to the Grant-Kearny line, 7 E.</b> Street address of well location if in city: <b>1 1/2 N., 1/8 E.</b>			3. Owner of well: <b>Tate-Spencer</b> R.R. or street: <b>Main Street</b> City, state, zip code: <b>Lakin, Kansas 67860</b>			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <b>26</b> in. Completion date <b>1-18-77</b> Well depth <b>374</b> ft.		
				7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material <u>steel</u> Height: Above ground <u>0</u> Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>36.87</u> lbs./ft. Dia. <u>16</u> in. to <u>375</u> ft. depth Wall Thickness: inches or Dia. <u>  </u> in. to <u>  </u> ft. depth gage No. <u>250, 219</u> MAC		
				10. Screen: Manufacturer's name <u>Johnson</u> Type <u>galv.</u> Dia. <u>16"</u> Slot <u>3/32"</u> Length <u>20</u> ft. Set between <u>340</u> ft. and <u>360</u> ft. Perf: <u>150-340</u> ft. and <u>360-374</u> ft. Gravel pack? <u>yes</u> Size range of material <u>1/2" down</u>		
				11. Static water level: <u>150</u> ft. below land surface Date <u>12-22-77</u> mo./day/yr.		
				12. Pumping level below land surfaces: <u>185</u> ft. after <u>2</u> hrs. pumping <u>1500</u> g.p.m. <u>  </u> ft. after <u>  </u> hrs. pumping <u>  </u> g.p.m. Estimated maximum yield <u>1500</u> g.p.m.		
				13. Water sample submitted: <u>  </u> mo./day/yr. <u>  </u> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <u>  </u>		
				14. Well head completion: <u>  </u> Pitless adapter <u>12</u> Inches above grade		
				15. Well grouted? <u>yes</u> With: <u>  </u> Neat cement <u>  </u> Bentonite <input checked="" type="checkbox"/> Concrete <u>  </u> Depth: From <u>0</u> ft. to <u>10</u> ft.		
				16. Nearest source of possible contamination: <u>N/A</u> ft. <u>  </u> Direction <u>  </u> Type <u>  </u> Well disinfected upon completion? <u>  </u> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>		
				17. Pump: <u>Not installed</u> Manufacturer's name <u>500/125</u> Model number <u>125</u> HP <u>150</u> Volts <u>  </u> Length of drop pipe <u>200</u> ft. capacity <u>1200</u> g.p.m. Type: <u>  </u> Submersible <input checked="" type="checkbox"/> Turbine <u>  </u> <u>  </u> Jet <u>  </u> Reciprocating <u>  </u> <u>  </u> Centrifugal <u>  </u> Other <u>  </u>		
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Minter-Wilson Drilling Co. 208</b> Business name <u>Box A Garden City, Ks.</u> License No. <u>  </u> Address <u>  </u> <u>9-20-77</u> Date <u>  </u> Authorized representative <u>  </u>		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

**MINTER-WILSON DRILLING CO.**  
INCORPORATED

Irrigation  
and Domestic  
Water Systems  
Complete Installation  
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

SPENCER AND TATE  
KEARNY COUNTY  
11-29-76

Location: SW 26-26-35 south of Lakin to county line 7 miles  
east 1 1/4 mile north 1/4 east

Static Water Level- 110

Test #1

0	22	Fine sand
22	35	Brown clay
35	54	Fine sand
54	93	Brown clay
93	110	Fine to med. sand and gravel 10% clay Loose
110	157	Fine to med. sand and gravel Loose (stks. of coarse gravel)
157	168	Blue clay
168	185	Fine to med. sand and gravel Loose
185	200	Fine to med. sand and gravel 10% clay Loose
200	296	Fine to med. sand and gravel Loose (stks. of coarse gravel)
296	322	Fine to med. sand and gravel loose
322	335	Fine to med. sand and gravel 15% clay Loose
335	374	Fine to med. sand and gravel loose
374	380	Brown clay 20% gravel Tight
380	428	Brown and gray clay with white rock Tight
428	440	Brown gray and yellow clay with brown rock Hard

Lost Circulation 440'  
T.D. 374